


REPORT V4251/1
OCTOBER 1978

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

HAT CREEK PROJECT
COOLING WATER SUPPLY
PRELIMINARY DESIGN STUDY
SUPPLEMENTARY INVESTIGATIONS





SANDWELL AND COMPANY LIMITED

SUITE 601 — 1550 ALBERNI STREET, VANCOUVER
B.C., CANADA V6G 1A4

TELEPHONE (604) 681-1111 AREA CODE 604
FACSIMILE (604) 681-1111 TELETYPE (604) 681-1111

31 October 1978

B. C. Hydro and Power Authority
Box 12121
555 West Hastings Street
Vancouver, B. C.
V6B 4T6

Attention: Mr. C. K. Harman, P. Eng.
Project Manager, Off-Site Facilities

Reference: V4251 Hat Creek Project
Cooling Water Supply
021.50 Preliminary Design Study
Supplementary Investigations

Dear Sirs:

We are pleased to present the attached copy of our Report V4251/1, Hat Creek Project, Cooling Water Supply, Preliminary Design Study, Supplementary Investigations, dated October 1978. Twenty copies have been sent to your attention under separate cover.

Yours truly

SANDWELL AND COMPANY LIMITED

A handwritten signature in cursive script, appearing to read 'A. Copeland', written over a horizontal line.

A. Copeland, P. Eng.
Project Engineer

AC/jc
Attachment: Report V4251/1

REPORT V4251/1
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PRELIMINARY DESIGN STUDY
SUPPLEMENTARY INVESTIGATIONS

DATE OCTOBER 1978

CONTENTS

SUMMARY

APPENDICES

1 Glossary of Terms

2 Project Memoranda

P.M. V4251/1 Pipeline Route Review
P.M. V4251/2 Pipeline - Breakdown of Cost Estimate
P.M. V4251/3 Water Treatment by Means of Settling
P.M. V4251/4 Reservoir Relocation
P.M. V4251/5 Thompson River - Water Level Data

REPORT V4251/1
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PRELIMINARY DESIGN STUDY
SUPPLEMENTARY INVESTIGATIONS

DATE OCTOBER 1978

SUMMARY

INTRODUCTION

In March 1978 Sandwell presented Report V4191/1, the Preliminary Design Study for the make-up water supply of B.C. Hydro's proposed 2000 MW* thermal power plant in the Hat Creek Valley near Ashcroft, B.C. Subsequent to that report, four supplementary investigations were carried out.

This report describes these investigations and also contains a breakdown of the Preliminary Design pipeline cost estimate. Investigations and cost breakdown are reported in five Project Memoranda, Appendix 2, a summary of which follows.

PIPELINE ROUTE REVIEW

In the Preliminary Design, a portion of the pipeline follows the 500 kV power transmission line planned to run due east from the power plant.

Project Memorandum V4251/1 reviews the pipeline route considering that the 500 kV transmission line would not be located in this area. In that case, the Preliminary Design scheme would change mainly as follows:

- | | |
|---|--|
| 1. Routing: | Section between Boston Flats and McLean Lake relocated. |
| 2. Length: | 22.4 km, 1.1 km shorter. |
| 3. Waterhammer Protection: | - One additional one-way surge tank. - Increased booster pump inertia at No. 2 Booster Station. |
| 4. Direct Capital Cost: | \$33,980,000, \$280,000 lower. |
| 5. Minimum Energy Cost, Present Value: | \$20,861,000, \$45,000 lower. |

* Mega-watt. For this and other abbreviations, see Appendix 1, Glossary of Terms.

RESERVOIR RELOCATION

In the Preliminary Design the cooling water supply reservoir is located in close proximity to the power plant.

Project Memorandum V4251/4 reviews the water supply system considering that the reservoir would be located in upper Medicine Creek approximately 1 km further away from the power plant and approximately 125 m lower than the originally proposed reservoir. As for P.M. V4251/1, this study also assumes that the 500 kV transmission line is not a factor in route selection.

A scheme is recommended which differs mainly as follows from the Preliminary Design:

1. Route:
 - Section between Boston Flats and McLean Lake relocated (follows route recommended in P.M. V4191/1).
 - Last 2 km of pipeline relocated.
2. Static Lift: 1013 m, 70 m lower.
3. Length: 21.4 km, 2.1 km shorter.
4. Pipeline Diameter: 7.3 km of 900 mm with the balance 800 mm, instead of 800 mm throughout.
5. Waterhammer Protection:
 - One additional simple surge tank.
 - Reduced booster pump inertia.
6. Inlet to Reservoir: Follows upstream end of reservoir valley instead of crossing under reservoir dam.
7. Total Capital Cost: \$46,000,000, \$1,400,000 lower.
8. Minimum Energy Cost, Present Value: \$15,699,000, \$5,207,000 lower, utilizing four million m³ per annum of Medicine Creek run-off.
9. Gravity Flow: 3.5 km of pipeline would flow by gravity, some of which partially full.

WATER TREATMENT BY MEANS OF SETTLING

Project Memorandum V4251/3 records and reviews water treatment proposals received during the Preliminary Design and recommends design parameters for a degritting clarifier. This method of treatment was selected during Preliminary Design to remove Thompson River water solids for the prevention of erosion in the high pressure pumps.


THOMPSON RIVER - WATER LEVEL DATA

Project Memorandum V4251/5 supplements water level data reported in the Preliminary Design Study for the proposed intake site. Water levels recorded here were taken at bimonthly intervals from 14 December 1977 until 1 July 1978.

PIPELINE - BREAKDOWN OF COST ESTIMATE

Project Memorandum V4251/2 records quantities, unit prices and breakdown of cost which were developed for the cost estimate of the water supply pipeline during Sandwell's Preliminary Design.

Prepared by



A. Copeland, P. Eng.

Approved by



Sandwell and Company Limited

APPENDIX 1
GLOSSARY OF TERMS

REPORT V4251/1
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PRELIMINARY DESIGN STUDY
SUPPLEMENTARY INVESTIGATIONS

DATE OCTOBER 1978

APPENDIX 1 - GLOSSARY OF TERMS

Terms and Some Abbreviations

| | |
|-------------------|--|
| a | annum |
| °C | degree Celcius |
| cm | centimetre |
| ft | foot |
| in | inch |
| kg | kilogram |
| km | kilometre |
| kWh | kilowatt hour |
| kPa | kilopascal |
| l/s | litre per second |
| m | metre |
| mm | millimetre |
| MW | mega-watt |
| m/s | metre per second |
| m ³ /s | cubic metre per second |
| micron | one thousandth of a mm |
| mill. | one thousandth of a dollar |
| pi/p | Instrument packages which travel through a pipeline propelled by the flow for inspection or cleaning purposes. |
| psi | pounds per square inch |
| psig | pounds per square inch gauge |
| s | second |
| sq | square |
| USGPM | United States gallons per minute |
| waterhammer | The waves of pressure which travel in a pipeline when changes in flow occur. |

Metric Units

| <u>Quantity</u> | <u>SI* Unit</u> | <u>Abbreviation</u> | <u>Equivalent</u> | <u>Imperial Unit</u> |
|-----------------|------------------------|---------------------|-------------------|-------------------------|
| Length | millimetre | mm | 0.03937 | inch |
| | centimetre | cm | 0.3937 | inch |
| | metre | m | 3.28 | feet |
| | | | 39.37 | inches |
| | kilometre | km | 0.6214 | mile |
| | | | 3280 | feet |
| Area | square metre | m ² | 10.87 | square feet |
| | hectare | ha | 2.471 | acres |
| Volume | cubic metre | m ³ | 35.314 | cubic feet |
| | litre | l | 264.17 0.2642 | US gallons US gallon |
| Discharge Rate | cubic metre per second | m ³ /s | 35.314 | cubic feet per second |
| | litre per second | l/s | 15.852 | US gallons per minute |
| Force | newton | N | 0.2248 | pounds |
| Mass | tonne | t | 2207 | pounds |
| | kilogram | kg. | 2.207 | pounds |
| Pressure | pascal | Pa | 0.000145 | pounds per square inch |
| | kilopascal | kPa | 0.145 | pounds per square inch |
| | megapascal | mPa | 145 | pounds per square inch |
| Power | kilowatt | kW | 1.34 | horsepower |
| Velocity | metre per second | m/s | 3.28 | feet per second |
| Inertia | kilogram metre square | kg. m ² | 0.737 | slug. feet square |

* International System of Units, as adopted by the Canadian Construction Industry.

APPENDIX 2
PROJECT MEMORANDA

PROJECT MEMORANDUM V4251/1

PIPELINE ROUTE REVIEW

SANDWELL
PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 23 JUNE 1978

PROJECT MEMORANDUM V4251/1
PIPELINE ROUTE REVIEW

CONTENTS

| | |
|----------------------|---|
| INTRODUCTION | 1 |
| ROUTES STUDIED | 1 |
| CAPITAL COST | 2 |
| OPERATING COST | 4 |
| OTHER CONSIDERATIONS | 4 |
| CONCLUSIONS | 6 |

APPENDICES

- 1 - References
- 2 - Illustrations

- B4251/1- 1 Pipeline Routes
- D4251/1- 2 Detailed Pipeline Routes
- D4251/1- 3 Pipeline Profiles

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 23 JUNE 1978

PROJECT MEMORANDUM V4251/1
PIPELINE ROUTE REVIEW

INTRODUCTION

In a letter to Mr. D. A. Brundrett of Sandwell, dated 22 February 1978, Mr. C. K. Harman of B.C. Hydro and Power Authority requested a review of the pipeline route described in Sandwell's Preliminary Design Study, Report V4191/1, March 1978. The reason for and extent of this review were given as follows:

"Review and select optimum pipeline route between Boston Flats and McLean Lake on the assumption that the 500 kV transmission line would not be located in this area. If a new pipeline route is chosen, select a new location for No. 2 booster station. Revise the drawings and cost estimates to reflect the new locations."

This memorandum records the studies done to determine the optimum route and presents the results. The selection of the optimum route is based on capital and operating cost, and on other considerations.

Rather than revising the previous drawings, Sandwell has prepared new drawings to show the routes studied. Cost estimate revisions have been limited to a cursory identification of cost differences rather than an in-depth review of the entire project estimate.

ROUTES STUDIED

The routes studied are shown on Drawings B4251/1-1 and D4251/1-2, and their profiles on Drawing D4251/1-3, all in Appendix 2. The routes are:

- Preliminary Design Route as presented in Sandwell Report V4191/1, March 1978.
- Alternatives 1, 2 and 3, which, including the booster station locations, were developed using maps and air photos, but without a field visit.

Alternative 1 avoids the lake at Station 11+000 and much of the rock excavation of the Preliminary Design Route.

Alternative 2 follows a strip of favourable topography and also avoids the rock and lake mentioned.

Alternative 3 is basically the same as the Conceptual Design Route (Report V4007/2, January 1977), except that it has been shifted about 1 km north at the top of the hill above Boston Flats to avoid some difficult terrain which became apparent during the helicopter survey on 8 November 1977.

A combination utilizing the lower portion of Alternative 3 with the upper portion of Alternative 2, joining after the booster station, was considered to reduce clearing on the upper portion of Alternative 2 while avoiding the eroding zone on its lower portion. However, as this combination would require extensive sidehill construction and would increase the pipeline length with few offsetting advantages, it was not developed.

The Preliminary Design Route requires two one-way surge tanks and increased booster pump inertia to control waterhammer pressures in the pipeline. B.C. Hydro assessed waterhammer control facilities only for the most promising Scheme, Alternative 3, and found that it requires an additional one-way surge tank (total of three) as well as increased booster pump inertia at No. 2 Booster Station. Waterhammer control facilities for Alternatives 1 and 2 were assumed to be the same as for the Preliminary Design Route.

Geotechnical stability was not appraised for each route alternative owing to time and budget limitations. Previous studies have resulted in favourable assessments of the area so that the routes shown are expected to be geotechnically acceptable.

Cost differences and other considerations were determined using air photos (Reference 1*), topographic maps (Reference 2), photographs and impressions from previous field visits.

CAPITAL COST

Only those items in the Preliminary Design cost estimate which vary significantly from route to route were included in the cost analysis.

The direct costs shown in Table 1 are for the section of pipeline where the route is altered - that is, from Station 5 + 560 to Station 14 + 150, using the original stationing from Report V4191/1. Unit prices from the Preliminary Design estimate have been used, which were based on the fourth quarter of 1977.

* For references, see Appendix 1

Table 1 - Partial Cost Estimate, Station 5 + 560 to 14 + 150

| Item | Preliminary Design | Alternative 1 | Alternative 2 | Alternative 3 | |
|---|----------------------------|------------------|------------------|------------------|--------------|
| <u>Dept. 272.00 - Water Pipeline</u> | | | | | |
| 272.63 | Grading | \$ 105,000 | \$ 77,200 | \$ 100,500 | \$ 78,900 |
| 272.65 | Pipe | 1,693,400 | 1,688,600 | 1,502,700 | 1,430,200 |
| 272.67 | Trenching | 1,278,800 | 1,292,300 | 1,256,300 | 1,267,300 |
| 272.70 | Line-up | 217,300 | 213,500 | 191,700 | 187,500 |
| 272.71 | Welding | 160,800 | 160,100 | 143,000 | 135,000 |
| 272.74 | Lower-in | 248,600 | 245,500 | 220,300 | 215,600 |
| 272.75 | Bedding | 127,000 | 90,900 | 124,200 | 96,800 |
| 272.78 | Backfill | 148,600 | 144,300 | 133,000 | 128,000 |
| 272.83 | Surge Tank Systems | - | * | * | 250,000 |
| 272.86 | Drainage Pipelines | 231,500 | 87,600 | 118,300 | 75,700 |
| Sub-Total | | 4,211,000 | \$ 4,000,000* | \$ 3,790,000* | \$ 3,865,000 |
| <u>Dept. 274.00 - No. 2 Booster Station</u> | | | | | |
| 274.86 | Drainage Pipelines | \$ 74,000 | \$ 74,000 | \$ 172,000 | \$ 240,000 |
| 274.93 | Overflow Reservoir | 890,000 | 890,000 | 690,000 | 620,000 |
| 274.94 | Access Roads | 35,000 | 43,000 | 108,000 | 155,000 |
| Sub-Total | | \$ 999,000 | \$ 1,007,000 | \$ 970,000 | \$ 1,015,000 |
| <u>Dept. 291.00 Power Supply & Distribution</u> | | | | | |
| 291.51 | 69 kV Transmission Line | - Nil - | \$ 3,000 | \$ 25,000 | \$ 50,000 |
| Sub-Total | | - Nil - | \$ 3,000 | \$ 25,000 | \$ 50,000 |
| Total of Partial Direct Cost | | \$5,210,000 | \$ 5,010,000* | \$ 4,785,000* | \$ 4,930,000 |

Notes on Capital Cost Estimate

- Items 272.63, 67, 75 and 78, respectively grading, trenching, bedding and backfill are influenced by the depth of rock under the surface. The assumptions for rock depth are shown on Drawing D4251/1-3.

* Waterhammer analyses would be necessary to determine if additional surge tanks are required. The cost of an extra tank would be about \$250,000.

2. Items 272.70, 71, and 74, respectively line-up, welding and lower-in, vary in accordance with the grade and wall thickness as shown on Drawing D4251/1-3.
3. Item 272.83, Surge Tank Systems, is based on analysis of the Preliminary Design Route and Alternative 3, but without analysis of Alternatives 1 and 2. Conceivably, 1 or 2 may require additional waterhammer control measures.
4. Item 272.86, drainage pipelines, is based on the drain points shown on Drawing D4251/1-2.
5. Items 274.86, the concrete-lined overflow trench at the second booster station, and 274.94, access roads, are as shown on Drawing D4251/1-2.
6. The overflow reservoir embankments, 274.93, are based on borrowed material as follows:

| | |
|--|-----------------------|
| Alternative 1, as for Preliminary Design | 97,000 m ³ |
| Alternative 2 | 72,500 m ³ |
| Alternative 3 | 63,000 m ³ |
7. B.C. Hydro and Power Authority was responsible for the design and cost estimate for the 69 kV transmission line during the Preliminary Design studies. Therefore, Item 291.51 was excluded from Report V4191/1, and only the extra length of line from the arc shown on Drawing D4191/2 is included here at \$31,000/km.

OPERATING COST

Energy cost for pumping over the 35 year project lifetime due to the friction of the extra pipeline length compared to the shortest route, Alternative 3, is as shown in Table 2.

Table 2 - Present Value of Energy Cost Based On
20 Mills per Kwh and 8% Interest

| <u>Route</u> | <u>Extra Length (m)</u> | <u>Minimum (Pumping at 725 l/s continuously)</u> | <u>Maximum (Pumping at 1,580 l/s for 46% of the time)</u> |
|--------------------|---------------------------------|--|---|
| Preliminary Design | 1,090 | \$ 45,000 | \$ 210,000 |
| Alternative 1 | 1,035 | 40,000 | 200,000 |
| Alternative 2 | 140 | 5,000 | 30,000 |
| Alternative 3 | 0 | 0 | 0 |

OTHER CONSIDERATIONS

The partial cost estimates in Table 1 do not reflect basic engineering design concepts and changes in unit prices which may be caused by differences in construction conditions. These aspects are shown and explained in Table 3, and each route is ranked from 1 (best) to 4 in each category.

Table 3 - Other Considerations of Pipeline Routings

| Item | Why Considered | Distinguishing Characteristic | Ranking* | | | |
|---|---|---|--------------------|---------------|---------------|---------------|
| | | | Preliminary Design | Alternative 1 | Alternative 2 | Alternative 3 |
| <u>CONSTRUCTION</u> | | | | | | |
| Steepness | Partial cost estimate does not distinguish the degree of steepness. | Slope from Boston Flats to First summit, approximately at El. 1300. | 1 | 2 | 4 | 3 |
| Sidehill construction | Cost is more for sidehill, as it requires an excavated working road. | Based on topographic maps. | 4 | 2 | 3 | 1 |
| General access | Cost of upgrading or building construction roads. | Distance from existing forest road network. | 1 | 2 | 3 | 4 |
| <u>DESIGN</u> | | | | | | |
| Spillage path | Potential for damage due to a pipeline breakage. | Worst - Highway junction at Boston Flats; Better-fields; hay fields at Boston Flats. Alternative 3 has a remote chance of flooding I.R.2. | 3 | 4 | 1 | 2 |
| Watercourse capacity for overflow from reservoir. | Affects size of outlet from overflow reservoir, therefore capacity of reservoir required. | Appearance on air photos and maps. | 3 | 2 | 4 | 1 |
| Crossing of Farmland | Disruption during construction, right-of-way cost. | Measured length. | 4 | 3 | 2 | 1 |
| Adjustability of route | Ease of making small route changes - flexibility. | Width of band in which route can be located. | 4 | 3 | 2 | 1 |
| Booster Station Location | Ease of construction and flexibility. | Adjustability of location and general site steepness. | 2 | 1 | 4 | 3 |
| Eroding Zones | Depth of bury of pipe may be increased. | Field photographs and air photos. | 1 | 3 | 4 | 2 |
| Overflow Reservoir | Adjustability in size and location. | Suitable alternative locations and capability for expansion. | 1 | 1 | 4 | 3 |
| TOTAL | | | 24 | 23 | 31 | 21 |

* Ranking is from 1 (best) to 4.

CONCLUSIONS

The capital and operating costs favour Alternatives 2 and 3 over Alternative 1 and the Preliminary Design Route. The cost differences are as follows:

Table 4 - Cost Differences

| <u>Item</u> | <u>Route</u> | | | |
|---|-------------------------------|--------------------------|--------------------------|--------------------------|
| | <u>Preliminary Design</u> | <u>Alternative 1</u> | <u>Alternative 2</u> | <u>Alternative 3</u> |
| Partial Capital Cost (Table 1) | \$ 5,210,000 | \$ 5,010,000* | \$ 4,785,000* | \$ 4,930,000 |
| Minimum Operating Cost (Table 2) | 45,000 | 40,000 | 5,000 | 0 |
| Total | \$ 5,255,000 | \$ 5,050,000* | \$ 4,790,000* | \$ 4,930,000 |
| Savings Relative to Preliminary Design | - | \$ 205,000* | \$ 465,000* | \$ 325,000 |
| Savings as % of Total Direct Cost of Preliminary Design | - | 0.6% | 1.4% | 0.9% |

The reasons why Alternatives 2 and 3 are more economical are mainly:

- Shorter pipe length.
- Fewer pipeline drainage facilities.
- Smaller overflow reservoir embankment.

The cost advantage of Alternative 3 over Alternative 2 would be reversed if Alternative 2 also needed an additional one-way surge tank. This difference is only 0.4 percent of the total direct cost.


Other considerations shown on Table 3 determine the selection of Alternative 3 rather than 2, as it ranks 10 points better. The superiority of Alternative 3 is mainly attributable to the categories sidehill construction, watercourse capacity for overflow, and passage through eroding zones, as well as slight advantages in five other categories. Alternative 2 has only slight advantages in two categories: general access and spillage path.

* Waterhammer analyses would be necessary to determine if additional surge tanks are required. The cost of an extra tank would be about \$250,000.

In conclusion, Alternative 3 offers cost savings and is in other ways superior to the other routes, and thus is recommended by Sandwell.

The route selection and booster station location should be confirmed by geotechnical evaluation and field appraisal.

Prepared by 
A. P. Basham, P. Eng.

Approved by 
A. Copeland, P. Eng.

APPENDIX 1

REFERENCES

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 23 JUNE 1978


PROJECT MEMORANDUM V4251/1
PIPELINE ROUTE REVIEW

APPENDIX 1 - REFERENCES

1. Four McElhanney Air Photographs - MA 1044-06315-0-6660 through -6663 of September 1976 (Approximate Scale 1" = 2400 ft).
2. Integrated Resources Photography Limited, Topographic Mapping, Project 77-245, prepared from reference 1, Sheets 3, 4 and 5 of October 1977.

APPENDIX 2


ILLUSTRATIONS



NOTES

- TOPOGRAPHY IS BASED ON FOLLOWING MAPS:
 - 1) FROM THE SURVEY AND MAPPING BRANCH OF THE B.C. LANDS SERVICE
 - 2) PLANNING MAPS NO. 92/1/100, 1/100 AND 1/100, SCALE 1" = 1/4 MI. COMPILED AND DRAWN BY THE AIR DIVISION IN 1960 FROM OFFICIAL SURVEYS AND FROM AERIAL PHOTOGRAPHS DATED 1950
 - 3) FOREST COVER MAP NO. 92/1/100, SCALE 1" = 1/4 MI. PREPARED BY THE B.C. FOREST SERVICE IN 1959
 - 4) FROM GEOLOGICAL SURVEY OF CANADA MAPS NO. 92/1/100 AND 92/1/100, SCALE 1" = 50,000, BASED ON 1952 INFORMATION AND PUBLISHED BY THEM IN 1960. CONTAINS ONLY.
- CONTOUR LINES ARE IN FEET.

LEGEND:
 --- MOAN RESERVE BOUNDARY
 --- HEIGHT OF LAND
 --- TRANSMISSION LINE




| | | |
|-------|-------|-----------|
| DES | REC'D | |
| DWN | SH | APP'D |
| CHK'D | KRS | APP'D |
| NSP | | R.C. |
| SUB'D | DATE | JUNE 1978 |

SANDWELL Dwg. No. 82-5- COLUMBIA HYDRO AND POWER AUTHORITY

HAT CREEK PROJECT
 COOLING WATER SUPPLY
 PIPELINE ROUTE REVIEW
 PIPELINE ROUTES


AS SHOWN Dwg. No. B 4251 / 1-1 R

| | | | |
|--------------------|--------------------|-----------|-----------|
| REFERENCE DRAWINGS | REFERENCE DRAWINGS | REVISIONS | REVISIONS |
|--------------------|--------------------|-----------|-----------|



- LEGEND:**
- 800 ϕ PIPELINE
 - 250 ϕ DEANLINE
 - BOOSTER STATION
 - OVERFLOW RESERVOIR
 - PROPOSED TRANSMISSION LINE (NOTE 4)
 - ▨ INDIAN RESERVES
 - ⊙ DUMP
 - ⊙ GP GRAVEL PIT
 - - - ACCESS ROAD

- NOTES:**
1. FOR PIPELINE PROFILES SEE REF 1.
 2. FOR GENERAL LOCATION SEE REF 2.
 3. STATIONING REFERS TO ORIGINAL STATIONING ALONG THE ROUTE IN REPORT V 4191/1. ONLY THE SECTION OF ROUTE BETWEEN STATIONS 5+560 AND 14+150 VARIES FROM THIS ROUTE.
 4. THE TRANSMISSION LINES SHOWN ARE THE EXTRA LENGTH REQUIRED FOR SUPPLY FROM A NEW SUBSTATION NEAR CACHE CREEK. THE LINES STOP SHORT OF THE BOOSTER STATION FOR CLARITY, AND RUN TO AN ARC INDICATING APPROXIMATE EQUAL DISTANCE FROM THE SUBSTATION.



| | |
|------------------------------|---|
| B 4251/1-1 PIPELINE ROUTES | 2 |
| D 4251/1-3 PIPELINE PROFILES | 1 |
| REFERENCE DRAWINGS | |

REFERENCE DRAWINGS

| NO. | REVISIONS | DATE | MADE | CHKD | INSP | SUBD | REC'D | APP'D | APP'D |
|-----|-----------|------|------|------|------|------|-------|-------|-------|
| | | | | | | | | | |


| | | |
|-------|-------|----------|
| DES | REC'D | |
| DWN | SH | APP'D |
| CHK'D | APP'D | |
| INSP | APP'D | A.C. |
| SUBD | DATE | JUNE 978 |

SANDWELL INC. NO. 1
 EST. IN COLUMBIA HYDRO AND POWER AUTHORITY

HAT CREEK PROJECT
COOLING WATER SUPPLY
 PIPELINE ROUTE REVIEW
 DETAILED PIPELINE ROUTES


AS SHOWN

D 4251/1-2 R




| II | 6 | II | 16 | 6 | II |
|-------|------|-------|-------|-------|----------------|
| 4.75 | 3.45 | 4.75 | 6.92 | 3.45 | 4.75 |
| 750 | 1350 | 880 | 870 | 2050 | 2080 |
| STEEP | FLAT | STEEP | STEEP | STEEP | FLAT |
| 2.01 | 2 | 1 | 0 | 0.1 | > 3 |
| 100 | 1700 | 1000 | 500 | 1700 | 200, 500, 2640 |

PRELIMINARY DESIGN ROUTE
SANDWELL REPORT V.4191/1




| II | 6 | II | 16 | 6 | II |
|-------|------|-------|---------------|-------|------|
| 4.75 | 3.45 | 4.75 | 6.92 | 3.45 | 4.75 |
| 800 | 1350 | 900 | 850 | 1250 | 50 |
| STEEP | FLAT | STEEP | STEEP | STEEP | FLAT |
| 2.01 | 2 | 1 | 0 | 0.1 | > 3 |
| 100 | 2240 | 1260 | 500, 300, 800 | | |

ALTERNATIVE #2



| II | 6 | II | 16 | 6 | II |
|-------|------|-------|-------|-------|------|
| 4.75 | 3.45 | 4.75 | 6.92 | 3.45 | 4.75 |
| 750 | 2300 | 835 | 930 | 750 | 1960 |
| STEEP | FLAT | STEEP | STEEP | STEEP | FLAT |
| 2.01 | 2 | 1 | 0 | 0.1 | > 3 |
| 100 | 2345 | 1 | 3380 | 1760 | |

ALTERNATIVE #1



| II | 6 | II | 16 | 6 | II |
|-------|------|-------|---------------|-------|------|
| 4.75 | 3.45 | 4.75 | 6.92 | 3.45 | 4.75 |
| 800 | 2750 | 800 | 750 | 400 | 600 |
| STEEP | FLAT | STEEP | STEEP | STEEP | FLAT |
| 2.01 | 2 | 1 | 0 | 0.1 | > 3 |
| 100 | 800 | 5800 | 500, 400, 500 | | |

ALTERNATIVE #3
RECOMMENDED

- NOTES:
- FOR DETAILED PRELIMINARY ROUTES SEE REF. 1.
 - STATIONING REFERS TO ORIGINAL STATIONING ALONG THE PRELIMINARY DESIGN ROUTE'S SANDWELL REPORT V.4191/1.
 - ON THE SECTION OF PIPELINE ROUTE MARKED # FOR WHICH DETAILS ARE PROVIDED DIFFERS FROM ROUTE TO ROUTE. THE LENGTHS MARKED # AND THOSE IN THE TABLES BELOW ARE TAKEN ALONG THE SLOPE.
 - WALL THICKNESS IN MM, DESIGN PRESSURE IN MPa, OTHERS IN METRES.



LEGEND
 ——— HYDRAULIC GRADE LINE
 - - - - - DESIGN GRADE LINE

| | | |
|-------|-------|-----------|
| DES | REC'D | |
| CHK'D | APP'D | |
| APP'D | | R.C. |
| DATE | | JUNE 1978 |

SANDWELL DWG. NO.
 BRUCE - COLUMBIA HYDRO AND POWER AUTHORITY
HAT CREEK PROJECT
 COOLING WATER SUPPLY
 PIPELINE ROUTE REVIEW
 PIPELINE PROFILES

PROJECT MEMORANDUM V4251/2

PIPELINE - BREAKDOWN OF COST ESTIMATE

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER B. C.

DATE 21 APRIL 1978

PROJECT MEMORANDUM V4251/2
PIPELINE
BREAKDOWN OF COST ESTIMATE

CONTENTS

PURPOSE AND BACKGROUND 1

APPENDICES

- 1 - Cost Breakdown
- 2 - Illustrations

B4251/2-1 Pipeline Route

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER B. C.

DATE 21 APRIL 1978

PROJECT MEMORANDUM V4251/2
PIPELINE
BREAKDOWN OF COST ESTIMATE

PURPOSE AND BACKGROUND

The purpose of this memorandum is to record quantities, unit prices and breakdown of cost which were developed for the cost estimate of the water supply pipeline, during Sandwell's Preliminary Design Study, Project V4191. The cost estimate recorded here comprises the pipeline from Thompson River intake to plant reservoir and is based on the Preliminary Design Study route proposed in Volume 1 of Sandwell's Report V4191/1 of March 1978. This route is also shown on Drawing B4251/2-1 in Appendix 2 of this memorandum.

To incorporate appropriate unit prices, the pipeline was divided into 14 sections. Appendix 1 contains a cost breakdown, quantities and unit prices for each of the 14 pipeline sections.

Table 1 on the following page is a summation of the pipeline costs broken down by sub accounts.


This table is identical to the one given on page 2 of Appendix 5, Details of Cost Estimate, Structures, contained in Volume 1 of Sandwell's Report V4191/1.

For a description of the basis of the estimates refer to Page 59, Volume 1, of Report V4191/1.


Table 1 - Details of Cost Estimate

| <u>Department 272 - Water Pipeline</u> | | <u>Material</u> | <u>Labour</u> | <u>Total</u> |
|--|-------------------------------|-----------------|---------------|---------------|
| 272.62 | Clearing | \$ - | \$ 115,000 | \$ 115,000 |
| 272.63 | Grading | - | 295,000 | 295,000 |
| 272.64 | Stockpile | - | 25,000 | 25,000 |
| 272.65 | Pipe | 4,880,000 | - | 4,880,000 |
| 272.66 | Haul and String | 25,000 | 315,000 | 340,000 |
| 272.67 | Trenching | - | 3,400 000 | 3,400 000 |
| 272.68 | Dewatering | 40,000 | 210,000 | 250,000 |
| 272.69 | Bending | - | 510,000 | 510,000 |
| 272.70 | Line-up | - | 525,000 | 525,000 |
| 272.71 | Welding | - | 450,000 | 450,000 |
| 272.72 | Patch Joints | 60,000 | 220,000 | 280,000 |
| 272.73 | Anchors | 10,000 | 20,000 | 30,000 |
| 272.74 | Lower-in and Tie-in | - | 640,000 | 640,000 |
| 272.75 | Bedding | 175,000 | 190,000 | 365,000 |
| 272.76 | X-Rays | 75,000 | - | 75,000 |
| 272.77 | Testing - Hydro and Pig | - | 120,000 | 120,000 |
| 272.78 | Backfill | 40,000 | 195,000 | 235,000 |
| 272.79 | Crossings - Road and Gaslines | 30,000 | 85,000 | 115,000 |
| 272.80 | Crossings - Railroad | 10,000 | 20,000 | 30,000 |
| 272.81 | Crossings - Stream | 80,000 | 175,000 | 255,000 |
| 272.82 | Clean-up and Hydro-Seeding | - | 195,000 | 195,000 |
| 272.86 | Drainage Pipelines | 335,000 | 970,000 | 1,305,000 |
| 272.87 | Access Manholes | 40,000 | 10,000 | 50,000 |
| 272.88 | Pig Traps | 745,000 | 180,000 | 925,000 |
| 272.90 | Land Cost | 120,000 | 5,000 | 125,000 |
| Total, Department 272 | | \$ 6,665,000 | \$ 8,870,000 | \$ 15,535,000 |

Prepared by


 B. N. Murphy

Approved by


 A. Copeland, P. Eng.

APPENDIX 1
COST BREAKDOWN

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 21 APRIL 1978

PROJECT MEMORANDUM V4251/2
PIPELINE
BREAKDOWN OF COST ESTIMATE

APPENDIX 1 - COST BREAKDOWN

The cost breakdown for the pipeline is given in the following 14 pages, each covering a section of the pipeline, as follows:

| Section | Station | | Length m | Total Cost \$(Rounded) | Average Cost \$/m |
|--|-----------|----------|-------------|------------------------------|-------------------------|
| | From m | To m | | | |
| 1 - From intake to first booster pumping station. | - | - | 697 | 450,000 | 645.6 |
| 2 - Starts at first booster pumping station. | 0 + 300 | 2 + 000 | 1700 | 1,205,000 | 708.8 |
| 3 - | 2 + 000 | 3 + 500 | 1500 | 1,305,000 | 870.0 |
| 4 - | 3 + 500 | 8 + 000 | 4500 | 2,700,000 | 600.0 |
| 5 - | 8 + 000 | 8 + 500 | 500 | 270,000 | 540.0 |
| 6 - | 8 + 500 | 8 + 800 | 300 | 230,000 | 766.7 |
| 7 - Includes piping around second booster pumping station. | 8 + 800 | 10 + 500 | 1700 | 1,700,000 | 1000.0 |
| 8 - | 10 + 500 | 11 + 000 | 500 | 435,000 | 870.0 |
| 9 - | 11 + 000 | 12 + 000 | 1000 | 775,000 | 775.0 |
| 10 - | 12 + 000 | 13 + 700 | 1700 | 965,000 | 567.6 |
| 11 - | 13 + 700 | 13 + 800 | 100 | 80,000 | 800.0 |
| 12 - | 13 + 800 | 18 + 500 | 4700 | 2,640,000 | 561.7 |
| 13 - | 18 + 500 | 20 + 500 | 2000 | 1,065,000 | 532.5 |
| 14 - | 20 + 500 | 23 + 090 | 2590 | 1,715,000 | 662.2 |
| Totals | | | 23487 m | \$15,535,000 | \$661.4 |

PIPELINE SECTION - 1

LENGTH: 697 m plus standpipe

FROM INTAKE
TO NO. 1 BOOSTER STATION

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|------------------------|------------|------------|----------|--------|---------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | Nil | - | - | - | - |
| .63 | Grading - Earth | 801 m | - | 5.0/m | - | 4,000 | 4,000 | - |
| | - Rock | - | - | - | - | - | - | - |
| .64 | Stockpile | - | - | Nil | - | - | - | - |
| .65 | Pipe - 800 ø x 8 mm Wall Thickness | - | - | - | - | - | - | - |
| | x 11 mm Wall Thickness | - | - | - | - | - | - | - |
| | x 17 mm Wall Thickness | - | - | - | - | - | - | - |
| | - 900 ø x 9 mm Wall Thickness | 734 m | 193.48/m | - | 142,015 | - | - | - |
| | - 1200 ø x 6.5 mm Wall Thickness | 102 m | 205.33/m | - | 20,945 | - | 182,960 | - |
| | Shop Bends and/or Tees | 4 | 5,000 | - | 20,000 | - | - | - |
| .66 | Haul and String | - | 1.00/m | 13.12/m | 840 | 11,000 | 11,840 | - |
| .67 | Trenching - All Soil to 3 m Depth | 80/m | - | 72.00/m | - | 57,675 | 57,675 | - |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | - |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | - |
| | - All Rock to 3 m Depth | - | - | - | - | - | - | - |
| .68 | Dewatering | 801 m | 1.65/m | 9.85/m | 1,320 | 7,890 | 9,210 | - |
| .69 | Bending | 801 m | - | 21.35/m | - | 17,100 | 17,100 | - |
| .70 | Line-up | 836 m | - | 20.00/m | - | 16,720 | 16,720 | - |
| .71 | Welding | 836 m | - | 18.00/m | - | 15,050 | 15,050 | - |
| .72 | Patch Joints | 836 m | 2.50/m | 9.15/m | 2,090 | 7,650 | 9,740 | - |
| .73 | Anchors | 125 m @ 38% | 2.00/m | 3.60/m | 250 | 450 | 700 | - |
| .74 | Lower-in and Tie-in | 801 m | - | 25.50/m | - | 20,425 | 20,425 | - |
| .75 | Bedding - Concrete | - | - | - | - | - | - | - |
| | - Mulch | 801 m | 0.65/m | 4.60/m | 480 | 3,725 | 4,205 | - |
| .76 | X-rays | - | 3.24/m | - | 2,710 | - | 2,710 | - |
| .77 | Testing - Hydro and Pig | 836 m | - | 5.00/m | - | 4,180 | 4,180 | - |
| .78 | Backfill | 801 m | - | 8.20/m | - | 6,570 | 6,570 | - |
| .79 | Crossings - Road and Gaslines - Open Cut | 20 m | - | 280.00/m | - | 5,600 | 5,600 | - |
| | - Bore and Case | 20 m | - | 985.00/m | - | 19,700 | 19,700 | - |
| .80 | Crossings - Railroad - Bore and Case | 20 m | - | 1,315.00/m | 9,000 | 20,400 | 29,400 | - |
| .81 | Crossings - Stream | Bonaparte River - L.S. | - | - | 4,000 | 16,000 | 20,000 | - |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 6,570 | 6,570 | - |
| .86 | Drainage Pipelines | - | - | - | - | - | - | - |
| .87 | Access Manholes | - | - | - | - | - | - | - |
| .88 | Pig Traps | - | - | - | - | - | - | - |
| .90 | Land Costs | 300 m | 5.20/m | 0.21/m | 1,560 | 65 | 1,625 | - |
| | Total | | | | | | 445,980 | \$639.9/m |
| | Total-Rounded | | | | | | 450,000 | 645.6/m |

PIPELINE SECTION - 2

LENGTH: 1700 m

FROM NO. 1 BOOSTER STATION
STATION 0 + 300
TO STATION 2 + 000

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|---------|------------|---------|----------|---------|---------|---------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | 1,700 m | - | 2.26/m | - | 3,845 | 3,845 | |
| .63 | Grading - Earth | 1,700 m | - | 5.00/m | - | 8,500 | 8,500 | |
| | - Rock | | - | - | - | - | - | |
| .64 | Stockpile | 1,700 | - | 1.15/m | - | 1,955 | 1,955 | |
| .65 | Pipe - 800 Ø x 8 mm Wall Thickness | - | - | - | - | - | - | |
| | x 11 mm Wall Thickness | - | - | - | - | - | - | |
| | x 17 mm Wall Thickness | 1,700 | 309.71/m | - | 526,510 | - | - | |
| | - 900 Ø x 9 mm Wall Thickness | - | - | - | - | - | - | |
| | - 1200 Ø x 6.5 mm Wall Thickness | - | - | - | - | - | 531,510 | |
| | Shop Bends and/or Tees | 1 | 5,000 | - | 5,000 | - | - | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 1,700 | 22,355 | 24,055 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | 72.00/m | - | 122,400 | 122,400 | |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | |
| | - All Rock to 3 m Depth | - | - | - | - | - | - | |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 2,805 | 16,745 | 19,550 | |
| .69 | Bending | - | - | 21.35/m | - | 36,295 | 36,295 | |
| .70 | Line-up | - | - | 20.00/m | - | 34,000 | 34,000 | |
| .71 | Welding | - | - | 18.00/m | - | 30,600 | 30,600 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 4,250 | 15,555 | 19,805 | |
| .73 | Anchors | - | - | - | - | - | - | |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 43,350 | 43,350 | |
| .75 | Bedding - Concrete | - | - | - | - | - | - | |
| | - Mulch | - | 0.65/m | 4.60/m | 1,105 | 7,820 | 8,925 | |
| .76 | X-rays | - | 3.24/m | - | 5,510 | - | 5,510 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 8,500 | 8,500 | |
| .78 | Backfill | - | - | 8.20/m | - | 13,940 | 13,940 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | 135 m | 280/m | - | 37,800 | 37,800 | |
| | - Bore and Case | - | - | - | - | - | - | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | - | - | - | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 13,940 | 13,940 | |
| .86 | Drainage Pipelines | - | - | - | - | - | - | |
| .87 | Access Manholes | - | - | - | - | - | - | |
| .88 | Pig Traps | - | 1 - L.S. | - | 185,960 | 44,740 | 230,700 | |
| .90 | Land Costs | - | 5.20/m | 0.21 | 8,840 | 335 | 9,195 | |
| | Total | | | | | | | 1,204,375 \$708.5/m |
| | Total-Rounded | | | | | | | 1,205,000 708.8/m |

(P.M. V4251/2, App. 1)

SANDWELL

PIPELINE SECTION - 3

LENGTH: 1500 m

FROM STATION 2 + 000

TO STATION 3 + 500

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|---------------|------------|----------|----------|-----------|-----------|----------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | 2.26/m | - | 3,390 | 3,390 | |
| .63 | Grading - Earth | - | - | - | - | - | - | |
| | - Rock | - | - | 74.00/m | - | 111,000 | 111,000 | |
| .64 | Stockpile | - | - | - | - | - | - | |
| .65 | Pipe - 800 Ø x 8 mm Wall Thickness | - | - | - | - | - | - | |
| | x 11 mm Wall Thickness | 640 m | 210.87/m | - | 177,130 | - | - | |
| | x 17 mm Wall Thickness | 660 m | 309.71/m | - | 204,410 | - | 381,540 | |
| | - 900 Ø x 9 mm Wall Thickness | - | - | - | - | - | - | |
| | - 1200 Ø x 6.5 mm Wall Thickness | - | - | - | - | - | - | |
| | Shop Bends and/or Tees | - | - | - | - | - | - | |
| .66 | Haul and String | 1,500 m | 1.00/m | 13/15/m | 1,500 | 19,725 | 21,225 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | |
| | - All Rock to 3 m Depth | - | - | 250.00/m | - | 375,000 | 375,000 | |
| .68 | Dewatering | - | - | - | - | - | - | |
| .69 | Bending | - | - | 21.35/m | - | 32,025 | 32,025 | |
| .70 | Line-up | - | - | 30.00/m | - | 45,000 | 45,000 | |
| .71 | Welding | - | - | 21.60/m | - | 32,400 | 32,400 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 3,750 | 13,725 | 17,475 | |
| .73 | Anchors | 1,500 m - 25% | 1.65/m | 3.15/m | 2,475 | 4,725 | 7,200 | |
| .74 | Lower-in and Tie-in | - | - | 32.00/m | - | 48,000 | 48,000 | |
| .75 | Bedding - Concrete | - | 60.00/m | 35.00/m | 90,000 | 52,500 | 142,500 | |
| | - Mulch | - | - | - | - | - | - | |
| .76 | X-rays | - | 3.24/m | - | 4,860 | - | 4,860 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 7,500 | 7,500 | |
| .78 | Backfill | - | 6.80/m | 8.00/m | 10,200 | 12,300 | 22,500 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | |
| | - Bore and Case | 20 m | - | 985.00/m | 7,880 | 11,820 | 19,700 | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | - | - | - | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20 | - | 12,300 | 12,300 | |
| .86 | Drainage Pipelines | - | - | - | - | - | - | |
| .87 | Access Manholes | - | L.S. | - | 9,200 | 2,000 | 11,200 | |
| .88 | Pig Traps | - | - | - | - | - | - | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 7,800 | 315 | 8,115 | |
| | Total | - | - | - | - | - | - | |
| | Total-Rounded | - | - | - | - | 1,302,930 | 1,305,000 | \$868.6/m 870.0/m |

(P.M. V4251, App. 1)

SNOWELL

PIPELINE SECTION -4

LENGTH: 4500 m

FROM STATION 3 + 500

TO STATION 8 + 000

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|---------------|------------|----------|----------|---------|-----------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | 2.26/m | - | 10,170 | 10,170 | |
| .63 | Grading - Earth | - | - | 5.00/m | - | 22,500 | 22,500 | |
| | - Rock | - | - | - | - | - | - | |
| .64 | Stockpile | - | - | 1.15 | - | 5,175 | 5,175 | |
| .65 | Pipe - 800 Ø x 8 mm Wall Thickness | 400 m | 160.24/m | - | 64,095 | - | - | |
| | x 11 mm Wall Thickness | 3,420 m | 210/87 m | - | 721,175 | - | - | |
| | x 17 mm Wall Thickness | 680 m | 309.71/m | - | 210,605 | - | - | |
| | - 900 Ø x 9 mm Wall Thickness | - | - | - | - | - | 1,005,875 | |
| | - 1200 Ø x 6.5 mm Wall Thickness | - | - | - | - | - | - | |
| | Shop Bends and/or Tees | 2 | 5,000 | - | 10,000 | - | - | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 4,500 | 59,175 | 63,675 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | 72.00/m | - | 324,000 | 324,000 | |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | |
| | - All Rock to 3 m Depth | - | - | - | - | - | - | |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 7,425 | 44,325 | 51,750 | |
| .69 | Bending | - | - | 21.35/m | - | 96,075 | 96,075 | |
| .70 | Line-up | - | - | 20.00/m | - | 90,000 | 90,000 | |
| .71 | Welding | - | - | 18.00/m | - | 81,000 | 81,000 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 11,250 | 41,175 | 52,425 | |
| .73 | Anchors | 1,500 m - 10% | 0.50/m | 1.00/m | 750 | 1,500 | 2,250 | |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 114,750 | 114,750 | |
| .75 | Bedding - Concrete | - | - | - | - | - | - | |
| | - Mulch | - | 0.65/m | 4.60/m | 2,925 | 20,700 | 23,625 | |
| .76 | X-rays | - | 3.24/m | - | 14,580 | - | 14,580 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 22,500 | 22,500 | |
| .78 | Backfill | - | - | 8.20/m | - | 36,900 | 36,900 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | |
| | - Bore and Case | 50 m | - | 985.00/m | 19,700 | 29,550 | 49,250 | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | - | - | - | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 36,900 | 36,900 | |
| .86 | Drainage Pipelines | 1 - 1,600 m | L.S. | - | 116,210 | 454,890 | 571,100 | |
| .87 | Access Manholes | - | - | - | - | - | - | |
| .88 | Pig Traps | - | - | - | - | - | - | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 23,400 | 945 | 24,345 | |
| | Total | - | - | - | - | - | 2,698,845 | \$599.7/m |
| | Total-Rounded | - | - | - | - | - | 2,700,000 | 600.0/m |

PIPELINE SECTION - 5

LENGTH: 500 m

FROM STATION 8 + 000

TO STATION 8 + 500

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|--------|------------|----------|----------|--------|--------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | 2.26/m | - | 1,130 | 1,130 | |
| .63 | Grading - Earth | - | - | 6.50/m | - | 3,250 | 3,250 | |
| | - Rock | - | - | - | - | - | - | |
| .64 | Stockpile | - | - | 1.15/m | - | 575 | 575 | |
| .65 | Pipe - 800 ø x 8 mm Wall Thickness | 500 m | 160.24/m | - | 80,120 | - | 80,120 | |
| | x 11 mm Wall Thickness | - | - | - | - | - | - | |
| | x 17 mm Wall Thickness | - | - | - | - | - | - | |
| | - 900 ø x 9 mm Wall Thickness | - | - | - | - | - | - | |
| | - 1200 ø x 6.5 mm Wall Thickness | - | - | - | - | - | - | |
| | Shop Bends and/or Tees | - | - | - | - | - | - | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 500 | 6,575 | 7,075 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | |
| | - 1 m Soil + 2 m Rock | - | - | 181.50/m | - | 90,750 | 90,750 | |
| | - All Rock to 3 m Depth | - | - | - | - | - | - | |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 825 | 4,925 | 5,750 | |
| .69 | Bending | - | - | 21.35/m | - | 10,675 | 10,675 | |
| .70 | Line-up | - | - | 30.00/m | - | 15,000 | 15,000 | |
| .71 | Welding | - | - | 21.60/m | - | 10,800 | 10,800 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 1,250 | 4,575 | 5,825 | |
| .73 | Anchors | - | 0.50 | 1.00 | 250 | 500 | 750 | |
| .74 | Lower-in and Tie-in | - | - | 32.00/m | - | 16,000 | 16,000 | |
| .75 | Bedding - Concrete | - | - | - | - | - | - | |
| | - Mulch | - | 0.65/m | 5.60/m | 325 | 2,300 | 2,625 | |
| .76 | X-rays | - | 3.24/m | - | 1,620 | - | 1,620 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 2,500 | 2,500 | |
| .78 | Backfill | - | 8.40/m | 8.20/m | 4,200 | 4,100 | 8,300 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | |
| | - Bore and Case | - | - | - | - | - | - | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | - | - | - | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 4,100 | 4,100 | |
| .86 | Drainage Pipelines | - | - | - | - | - | - | |
| .87 | Access Manholes | - | - | - | - | - | - | |
| .88 | Pig Traps | - | - | - | - | - | - | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 2,600 | 105 | 2,705 | |
| | Total | | | | | | | 269,550 \$539.1/m |
| | Total-Rounded | | | | | | | 270,000 540.0/m |

(P.M. V4251/2, App. 1)

PIPELINE SECTION - 6

LENGTH: 300 m

FROM STATION 8 + 500

TO STATION 8 + 800

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|-------------|------------|----------|----------|--------|---------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | 6.80/m | - | 2,040 | 2,040 | |
| .63 | Grading - Earth | - | - | - | - | - | - | |
| | - Rock | - | - | 74.00/m | - | 22,200 | 22,200 | |
| .64 | Stockpile | - | - | - | - | - | - | |
| .65 | Pipe - 800 ø x 8 mm Wall Thickness | 300 m | 160.24/m | - | 48,075 | - | 48,075 | |
| | x 11 mm Wall Thickness | - | - | - | - | - | - | |
| | x 17 mm Wall Thickness | - | - | - | - | - | - | |
| | - 900 ø x 9 mm Wall Thickness | - | - | - | - | - | - | |
| | - 1200 ø x 6.5 mm Wall Thickness | - | - | - | - | - | - | |
| | Shop Bends and/or Tees | - | - | - | - | - | - | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 300 | 3,945 | 4,245 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | |
| | - All Rock to 3 m Depth | - | - | 250.00/m | - | 75,000 | 75,000 | |
| .68 | Dewatering | - | - | - | - | - | - | |
| .69 | Bending | - | - | 21.35/m | - | 6,405 | 6,405 | |
| .70 | Line-up | - | - | 30.00/m | - | 9,000 | 9,000 | |
| .71 | Welding | - | - | 21.60/m | - | 6,480 | 6,480 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 750 | 2,745 | 3,495 | |
| .73 | Anchors | 300 m - 25% | 1.65/m | 3.15/m | 495 | 945 | 1,440 | |
| .74 | Lower-in and Tie-in | - | - | 32.00/m | - | 9,600 | 9,600 | |
| .75 | Bedding - Concrete | - | 60.00/m | 35.00/m | 18,000 | 10,500 | 28,500 | |
| | - Mulch | - | - | - | - | - | - | |
| .76 | X-rays | - | 3.24/m | - | 970 | - | 970 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 1,500 | 1,500 | |
| .78 | Backfill | - | 6.80/m | 8.20/m | 2,040 | 2,460 | 4,500 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | |
| | - Bore and Case | - | - | - | - | - | - | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | - | - | - | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 2,460 | 2,460 | |
| .86 | Drainage Pipelines | - | - | - | - | - | - | |
| .87 | Access Manholes | - | - | - | - | - | - | |
| .88 | Pig Traps | - | - | - | - | - | - | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 1,560 | 65 | 1,625 | |
| | Total | - | - | - | - | - | 227,535 | \$758.5/m |
| | Total-Rounded | - | - | - | - | - | 230,000 | 766.7/m |

(P.M. V4251/2, App. 1)

PIPELINE SECTION - 7

LENGTH: 1700 m

FROM STATION 8 + 800

TO STATION 10 + 500

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|---------------|------------|----------|----------|---------|-----------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | 7.05/m | - | 13,925 | 13,925 | |
| .63 | Grading - Earth | - | - | 6.50/m | - | 12,840 | 12,840 | |
| | - Rock | - | - | - | - | - | - | |
| .64 | Stockpile | - | - | 1.15/m | - | 2,275 | 2,275 | |
| .65 | Pipe - 800 ø x 8 mm Wall Thickness | 955 m | 160.24/m | - | 153,030 | - | - | |
| | x 11 mm Wall Thickness | - | - | - | - | - | - | |
| | x 17 mm Wall Thickness | 870 m | 309.71/m | - | 269,450 | - | - | |
| | - 900 ø x 9 mm Wall Thickness | - | - | - | - | - | - | |
| | - 1200 ø x 6.5 mm Wall Thickness | 150 m | 205.33/m | - | 30,800 | - | 458,280 | |
| | Shop Bends and/or Tees | 1 | 5,000 ea | - | 5,000 | - | - | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 1,975 | 25,975 | 27,950 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | |
| | - 1 m Soil + 2 m Rock | - | - | 181.50/m | - | 358,465 | 358,465 | |
| | - All Rock to 3 m Depth | - | - | - | - | - | - | |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 3,260 | 19,455 | 22,715 | |
| .69 | Bending | - | - | 21.35/m | - | 42,170 | 42,170 | |
| .70 | Line-up | - | - | 30.00/m | - | 59,250 | 59,250 | |
| .71 | Welding | - | - | 21.60/m | - | 42,660 | 42,660 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 4,940 | 18,070 | 23,010 | |
| .73 | Anchors | 1,700 m - 15% | 1.00/m | 1.80/m | 1,975 | 3,555 | 5,530 | |
| .74 | Lower-in and Tie-in | - | - | 32.00/m | - | 63,200 | 63,200 | |
| .75 | Bedding - Concrete | - | - | - | - | - | - | |
| | - Mulch | - | 0.65/m | 4.60/m | 1,285 | 9,085 | 10,370 | |
| .76 | X-rays | - | 3.24 | - | 5,510 | - | 5,510 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 9,875 | 9,875 | |
| .78 | Backfill | - | - | 8.20/m | - | 16,195 | 16,195 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | |
| | - Bore and Case | - | - | - | - | - | - | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | - | - | - | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 16,195 | 16,195 | |
| .86 | Drainage Pipelines | #2- | L.S. | L.S. | 21,230 | 13,650 | 34,880 | |
| .87 | Access Manholes | - | - | - | - | - | - | |
| .88 | Pig Traps | 2 | L.S. | L.S. | 371,920 | 89,480 | 461,400 | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 8,840 | 355 | 9,195 | |
| | Total | | | | | | 1,695,890 | \$997.6/m |
| | Total-Rounded | | | | | | 1,700,000 | 1000.0/m |

(P.M. V4251/2, App. 1)

PIPELINE SECTION 8

LENGTH: 500 m

FROM STATION 10 + 500

TO STATION 11 + 000

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m | |
|---------|--|--------|--------------------------|----------|----------|---------|---------|-------------------|--|
| | | | Material | Labour | Material | Labour | Total | | |
| 272.62 | Clearing | - | - | 9.05/m | - | 4,525 | 4,525 | | |
| .63 | Grading - Earth | - | - | - | - | - | - | | |
| | - Rock | - | - | 74.00/m | - | 37,000 | 37,000 | | |
| .64 | Stockpile | - | - | - | - | - | - | | |
| .65 | Pipe - 800 ø x 8 mm Wall Thickness | - | - | - | - | - | - | | |
| | x 11 mm Wall Thickness | 500 m | 210.87 | - | 105,435) | - | - | | |
| | x 17 mm Wall Thickness | - | - | - | - | - | - | | |
| | - 900 ø x 9 mm Wall Thickness | - | - | - | - | - | 115,435 | | |
| | - 1200 ø x 6.5 mm Wall Thickness | - | - | - | - | - | - | | |
| | Shop Bends and/or Tees | 2 | 5,000 | - | 10,000) | - | - | | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 500 | 6,575 | 7,075 | | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | | |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | | |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | | |
| | - All Rock to 3 m Depth | - | - | 250.00/m | - | 125,000 | 125,000 | | |
| .68 | Dewatering | - | Plus Pump Out Lake-Allow | 1.65/m | 9.85/m | 3,000 | 12,000 | 15,000 | |
| .69 | Bending | - | - | 21.35/m | - | 10,675 | 10,675 | | |
| .70 | Line-up | - | - | 30.00/m | - | 15,000 | 15,000 | | |
| .71 | Welding | - | - | 21.60/m | - | 10,800 | 10,800 | | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 1,250 | 4,575 | 5,825 | | |
| .73 | Anchors | 25% | 1.65 | 3.15 | 825 | 1,575 | 2,400 | | |
| .74 | Lower-in and Tie-in | - | - | 32.00/m | - | 16,000 | 16,000 | | |
| .75 | Bedding - Concrete | - | 60.00/m | 35.00/m | 30,000 | 17,500 | 47,500 | | |
| | - Mulch | - | - | - | - | - | - | | |
| .76 | X-rays | - | 3.24/m | - | 1,620 | - | 1,620 | | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 2,500 | 2,500 | | |
| .78 | Backfill | - | 6.80/m | 8.20/m | 3,400 | 4,100 | 7,500 | | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | | |
| | - Bore and Case | - | - | - | - | - | - | | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | | |
| .81 | Crossings - Stream | - | - | - | - | - | - | | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 4,100 | 4,100 | | |
| .86 | Drainage Pipelines | - | - | - | - | - | - | | |
| .87 | Access Manholes | - | - | - | - | - | - | | |
| .88 | Pig Traps | - | - | - | - | - | - | | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 2,600 | 105 | 2,705 | | |
| | Total | - | - | - | - | - | 430,660 | \$861.3/m | |
| | Total-Rounded | - | - | - | - | - | 435,000 | 870.0/m | |

PIPELINE SECTION 9

LENGTH: 1000m

FROM STATION 11 + 000

TO STATION 12 + 000

| Account | Description | Amount | Unit Price | | Cost | | Average Cost \$/m |
|---------|--|-----------------|------------|----------|----------|---------|-------------------|
| | | | Material | Labour | Material | Labour | |
| 272.62 | Clearing | - | - | 9.05/m | - | 9,050 | 9,050 |
| .63 | Grading - Earth | - | - | 5.00/m | - | 5,000 | 5,000 |
| | - Rock | - | - | - | - | - | - |
| .64 | Stockpile | - | - | 1.15/m | - | 1,150 | 1,150 |
| .65 | Pipe - 800 Ø x 8 mm Wall Thickness | 600 m | 160.24/m | - | 96,145 | - | 180,495 |
| | x 11 mm Wall Thickness | 400 m | 210.87/m | - | 84,350 | - | - |
| | x 17 mm Wall Thickness | - | - | - | - | - | - |
| | - 900 Ø x 9 mm Wall Thickness | - | - | - | - | - | - |
| | - 1200 Ø x 6.5 mm Wall Thickness | - | - | - | - | - | - |
| | Shop Bends and/or Tees | - | - | - | - | - | - |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 1,000 | 13,150 | 14,150 |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - |
| | - 1 m Soil + 2 m Rock | - | - | 181.50/m | - | 181,500 | 181,500 |
| | - All Rock to 3 m Depth | - | - | - | - | - | - |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 1,650 | 9,850 | 11,500 |
| .69 | Bending | - | - | 21.35/m | - | 21,350 | 21,350 |
| .70 | Line-up | - | - | 20.00/m | - | 20,000 | 20,000 |
| .71 | Welding | - | - | 18.00/m | - | 18,000 | 18,000 |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 2,500 | 9,150 | 11,650 |
| .73 | Anchors | - | 0.50/m | 1.00/m | 500 | 1,000 | 1,500 |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 25,500 | 25,500 |
| .75 | Bedding - Concrete | - | - | - | - | - | - |
| | - Mulch | - | 0.65/m | 4.60/m | 650 | 4,600 | 5,250 |
| .76 | X-rays | - | 3.24/m | - | 3,240 | - | 3,240 |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 5,000 | 5,000 |
| .78 | Backfill | - | - | 8.20/m | - | 8,200 | 8,200 |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - |
| | - Bore and Case | - | - | - | - | - | - |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - |
| .81 | Crossings - Stream | - | - | - | - | - | - |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 8,200 | 8,200 |
| .86 | Drainage Pipelines | #3 - 500 m L.S. | - | - | 53,160 | 170,955 | 224,115 |
| .87 | Access Manholes | 1 - L.S. | - | - | 9,200 | 2,000 | 11,200 |
| .88 | Pig Traps | - | - | - | - | - | - |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 5,200 | 210 | 5,410 |
| | Total | - | - | - | - | - | 771,460 \$771.5/m |
| | Total-Rounded | - | - | - | - | - | 775,000 775.0/m |

(P.M. V4251/2, App. 1)

SANDWELL

PIPELINE SECTION 10

LENGTH: 1700 m

FROM STATION 12 + 000

TO STATION 13 + 700

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|-----------------|------------|---------|----------|---------|---------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | 6.92/m | - | 11,765 | 11,765 | |
| .63 | Grading - Earth | - | - | 5.50/m | - | 9,350 | 9,350 | |
| | - Rock | - | - | - | - | - | - | |
| .64 | Stockpile | - | - | 1.15/m | - | 1,955 | 1,955 | |
| .65 | Pipe - 800 Ø x 8 mm Wall Thickness | 1,380 m | 160.24/m | - | 221,135 | - | 221,135 | |
| | x 11 mm Wall Thickness | 320 m | 210.87 | - | 67,480 | - | 67,480 | |
| | x 17 mm Wall Thickness | - | - | - | - | - | - | |
| | - 900 Ø x 9 mm Wall Thickness | - | - | - | - | - | - | |
| | - 1200 Ø x 6.5 mm Wall Thickness | - | - | - | - | - | - | |
| | Shop Bends and/or Tees | - | - | - | - | - | - | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 1,700 | 22,355 | 24,055 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | |
| | - 2 m Soil + 1 m Rock | - | 145.00/m | - | - | 246,500 | 246,500 | |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | |
| | - All Rock to 3 m Depth | - | - | - | - | - | - | |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 2,805 | 16,745 | 19,550 | |
| .69 | Bending | - | - | 21.35/m | - | 36,295 | 36,295 | |
| .70 | Line-up | - | - | 20.00/m | - | 34,000 | 34,000 | |
| .71 | Welding | - | - | 18.00/m | - | 30,600 | 30,600 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 4,250 | 15,555 | 19,805 | |
| .73 | Anchors | - | 0.50/m | 1.00/m | 850 | 1,700 | 2,550 | |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 43,350 | 43,350 | |
| .75 | Bedding - Concrete | - | - | - | - | - | - | |
| | - Mulch | - | 0.65/m | 4.60/m | 1,105 | 7,820 | 8,925 | |
| .76 | X-rays | - | 3.24/m | - | 5,510 | - | 5,510 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 8,500 | 8,500 | |
| .78 | Backfill | - | - | 8.20/m | - | 13,940 | 13,940 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | |
| | - Bore and Case | - | - | - | - | - | - | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | - | - | - | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 13,940 | 13,940 | |
| .86 | Drainage Pipelines | #4 - 300 m L.S. | - | - | 38,350 | 93,710 | 132,060 | |
| .87 | Access Manholes | - | - | - | - | - | - | |
| .88 | Pig Traps | - | - | - | - | - | - | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 8,840 | 355 | 9,195 | |
| | Total | | | | | | 960,460 | \$565.0/m |
| | Total-Rounded | | | | | | 965,000 | 567.6/m |

PIPELINE SECTION 11

LENGTH: 100 m

FROM STATION 13 + 700

TO STATION 13 + 800

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|--------|------------|----------|----------|--------|--------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | - | - | - | - | - |
| .63 | Grading - Earth | - | - | - | - | - | - | - |
| | - Rock | - | - | 74.00/m | - | 7,400 | 7,400 | - |
| .64 | Stockpile | - | - | - | - | - | - | - |
| .65 | Pipe - 800 ϕ x 8 mm Wall Thickness | - | - | - | - | - | - | - |
| | x 11 mm Wall Thickness | 100 m | 210.87/m | - | 21,087 | - | 21,087 | - |
| | x 17 mm Wall Thickness | - | - | - | - | - | - | - |
| | - 900 ϕ x 9 mm Wall Thickness | - | - | - | - | - | - | - |
| | - 1200 ϕ x 6.5 mm Wall Thickness | - | - | - | - | - | - | - |
| | Shop Bends and/or Tees | - | - | - | - | - | - | - |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 100 | 1,315 | 1,415 | - |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | - |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - | - |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | - |
| | - All Rock to 3 m Depth | - | - | 250.00/m | - | 25,000 | 25,000 | - |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 165 | 985 | 1,150 | - |
| .69 | Bending | - | - | 21.35/m | - | 2,135 | 2,135 | - |
| .70 | Line-up | - | - | 20.00/m | - | 2,000 | 2,000 | - |
| .71 | Welding | - | - | 18.00/m | - | 1,800 | 1,800 | - |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 250 | 915 | 1,165 | - |
| .73 | Anchors | - | - | - | - | - | - | - |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 2,550 | 2,550 | - |
| .75 | Bedding - Concrete | - | 60.00/m | 35.00/m | 6,000 | 3,500 | 9,500 | - |
| | - Mulch | - | - | - | - | - | - | - |
| .76 | X-rays | - | 3.24/m | - | 325 | - | 325 | - |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 500 | 500 | - |
| .78 | Backfill | - | 6.80/m | 8.20/m | 680 | 820 | 1,500 | - |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | - |
| | - Bore and Case | - | - | - | - | - | - | - |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | - |
| .81 | Crossings - Stream | - | - | - | - | - | - | - |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 820 | 820 | - |
| .86 | Drainage Pipelines | - | - | - | - | - | - | - |
| .87 | Access Manholes | - | - | - | - | - | - | - |
| .88 | Pig Traps | - | - | - | - | - | - | - |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 520 | 20 | 540 | - |
| | Total | - | - | - | - | - | 78,890 | \$788.9/m |
| | Total-Rounded | - | - | - | - | - | 80,000 | 800.0/m |

(P.M. V4251/2, App. 1)

PIPELINE SECTION 12

LENGTH: 4700m

FROM STATION 13 + 800

TO STATION 18 + 500

| Account | Description | Amount | Unit Price | | Cost | | | Average Cost \$/m |
|---------|--|---------|------------|----------|----------|---------|-----------|-------------------|
| | | | Material | Labour | Material | Labour | Total | |
| 272.62 | Clearing | - | - | 6.22/m | - | 29,235 | 29,235 | |
| .63 | Grading - Earth | - | - | 5.50/m | - | 25,850 | 25,850 | |
| | - Rock | - | - | - | - | - | - | |
| .64 | Stockpile | - | - | 1.15/m | - | 5,405 | 5,405 | |
| .65 | Pipe - 800 Ø x 8 mm Wall Thickness | 2,890 m | 160.24/m | - | 463,095 | - | 844,770 | |
| | x 11 mm Wall Thickness | 1,810 m | 210.81/m | - | 381,675 | - | - | |
| | x 17 mm Wall Thickness | - | - | - | - | - | - | |
| | - 900 Ø x 9 mm Wall Thickness | - | - | - | - | - | - | |
| | - 1200 Ø x 6.5 mm Wall Thickness | - | - | - | - | - | - | |
| | Shop Bends and/or Tees | - | - | - | - | - | - | |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 4,700 | 61,805 | 66,505 | |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - | |
| | - 2 m Soil + 1 m Rock | - | - | 145.00/m | - | 681,500 | 681,500 | |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - | |
| | - All Rock to 3 m Depth | - | - | - | - | - | - | |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 7,755 | 46,295 | 54,050 | |
| .69 | Bending | - | - | 21.35/m | - | 100,345 | 100,345 | |
| .70 | Line-up | - | - | 20.00/m | - | 94,000 | 94,000 | |
| .71 | Welding | - | - | 18.00/m | - | 84,600 | 84,600 | |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 11,750 | 43,005 | 54,755 | |
| .73 | Anchors | - | 0.50/m | 1.00/m | 2,350 | 4,700 | 7,050 | |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 119,850 | 119,850 | |
| .75 | Bedding - Concrete | - | - | - | - | - | - | |
| | - Mulch | - | 0.65/m | 4.60/m | 3,055 | 21,620 | 24,675 | |
| .76 | X-rays | - | 3.24/m | - | 15,230 | - | 15,230 | |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 23,500 | 23,500 | |
| .78 | Backfill | - | - | 8.20/m | - | 38,540 | 38,540 | |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - | |
| | - Bore and Case | - | - | - | - | - | - | |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - | |
| .81 | Crossings - Stream | - | - | - | 74,415 | 159,505 | 233,920 | |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20 | - | 38,540 | 38,540 | |
| .86 | Drainage Pipelines | - | - | - | 38,900 | 28,480 | 67,380 | |
| .87 | Access Manholes | - | - | - | - | - | - | |
| .88 | Pig Traps | - | - | - | - | - | - | |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 24,440 | 985 | 25,425 | |
| | Total | - | - | - | - | - | 2,635,125 | \$560.7/m |
| | Total-Rounded | - | - | - | - | - | 2,640,000 | 561.7/m |

SANDWELL

PIPELINE SECTION 13
LENGTH: 2000 m

FROM STATION 18 + 500
TO STATION 20 + 500

| Account | Description | Amount | Unit Price | | Cost | | Average Cost \$/m |
|---------|--|-----------------|------------|---------|----------|---------|-------------------|
| | | | Material | Labour | Material | Labour | |
| 272.62 | Clearing | - | - | 4.08/m | - | 8,160 | 8,160 |
| .63 | Grading - Earth | - | - | 5.00/m | - | 10,000 | 10,000 |
| | - Rock | - | - | - | - | - | - |
| .64 | Stockpile | - | - | 1.15/m | - | 2,300 | 2,300 |
| .65 | Pipe - 800 ø x 8 mm Wall Thickness | 2,000 m | 160.24/m | - | 320,480 | - | 320,480 |
| | x 11 mm Wall Thickness | - | - | - | - | - | - |
| | x 17 mm Wall Thickness | - | - | - | - | - | - |
| | - 900 ø x 9 mm Wall Thickness | - | - | - | - | - | - |
| | - 1200 ø x 6.5 mm Wall Thickness | - | - | - | - | - | - |
| | Shop Bends and/or Tees | - | - | - | - | - | - |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 2,000 | 26,300 | 28,300 |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - |
| | - 2 m Soil + 1 m Rock | - | - | - | - | - | - |
| | - 1 m Soil + 2 m Rock | - | - | 181.50 | - | 363,000 | 363,000 |
| | - All Rock to 3 m Depth | - | - | - | - | - | - |
| .68 | Dewatering | - | 1.65/m | 1.85/m | 3,300 | 3,700 | 7,000 |
| .69 | Bending | - | - | 21.35/m | - | 42,700 | 42,700 |
| .70 | Line-up | - | - | 20.00/m | - | 40,000 | 40,000 |
| .71 | Welding | - | - | 18.00/m | - | 36,000 | 36,000 |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 5,000 | 18,300 | 23,300 |
| .73 | Anchors | - | - | - | - | - | - |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 51,000 | 51,000 |
| .75 | Bedding - Concrete | - | - | - | - | - | - |
| | - Mulch | - | 0.65/m | 4.60/m | 1,300 | 9,200 | 10,500 |
| .76 | X-rays | - | 3.24/m | - | 6,480 | - | 6,480 |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 10,000 | 10,000 |
| .78 | Backfill | - | - | 8.20/m | - | 16,400 | 16,400 |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - |
| | - Bore and Case | - | - | - | - | - | - |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - |
| .81 | Crossings - Stream | - | - | - | - | - | - |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 16,400 | 16,400 |
| .86 | Drainage Pipelines | #7 - 100 m L.S. | - | - | 21,695 | 40,300 | 61,995 |
| .87 | Access Manholes | - | - | - | - | - | - |
| .88 | Pig Traps | - | - | - | - | - | - |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 10,400 | 420 | 10,820 |
| | Total | | | | | | 1,064,835 |
| | Total-Rounded | | | | | | 1,065,000 |

(P.M. Vh251/2, App. 1)

PIPELINE SECTION 14

LENGTH: 2590 m

FROM STATION 20 + 500


TO STATION 23 + 090

| Account | Description | Amount | Unit Price | | Cost | | Average Cost \$/m |
|---------|--|-----------------|------------|----------|----------|---------|---------------------|
| | | | Material | Labour | Material | Labour | |
| 272.62 | Clearing | - | - | 5.50/m | - | 14,245 | 14,245 |
| .63 | Grading - Earth | - | - | 5.00/m | - | 12,950 | 12,950 |
| | - Rock | - | - | - | - | - | - |
| .64 | Stockpile | - | - | 1.15/m | - | 2,980 | 2,980 |
| .65 | Pipe - 800 ϕ x 8 mm Wall Thickness | 2,590 m | 160.24 | - | 415,025 | - | - |
| | x 11 mm Wall Thickness | - | - | - | - | - | - |
| | x 17 mm Wall Thickness | - | - | - | - | - | - |
| | - 900 ϕ x 9 mm Wall Thickness | - | - | - | - | - | 420,025 |
| | - 1200 ϕ x 6.5 mm Wall Thickness | - | - | - | - | - | - |
| | Shop Bends and/or Tees | 1 | 5,000 | - | 5,000 | - | - |
| .66 | Haul and String | - | 1.00/m | 13.15/m | 2,590 | 34,060 | 36,650 |
| .67 | Trenching - All Soil to 3 m Depth | - | - | - | - | - | - |
| | - 2 m Soil + 1 m Rock | - | - | 145.00/m | - | 375,550 | 375,550 |
| | - 1 m Soil + 2 m Rock | - | - | - | - | - | - |
| | - All Rock to 3 m Depth | - | - | - | - | - | - |
| .68 | Dewatering | - | 1.65/m | 9.85/m | 4,275 | 25,515 | 29,790 |
| .69 | Bending | - | - | 21.35/m | - | 55,300 | 55,300 |
| .70 | Line-up | - | - | 20.00/m | - | 51,800 | 51,800 |
| .71 | Welding | - | - | 18.00/m | - | 46,620 | 46,620 |
| .72 | Patch Joints | - | 2.50/m | 9.15/m | 6,475 | 23,700 | 30,175 |
| .73 | Anchors | - | - | - | - | - | - |
| .74 | Lower-in and Tie-in | - | - | 25.50/m | - | 66,045 | 66,045 |
| .75 | Bedding - Concrete | 250 m | 60.00 | 35.00 | 15,000 | 8,750 | 23,750 |
| | - Mulch | 2,590 m | 0.65/m | 4.60/m | 1,685 | 11,915 | 13,600 |
| .76 | X-rays | - | 3.24/m | - | 8,390 | - | 8,390 |
| .77 | Testing - Hydro and Pig | - | - | 5.00/m | - | 12,950 | 12,950 |
| .78 | Backfill | - | - | 8.20/m | - | 21,240 | 21,240 |
| .79 | Crossings - Road and Gaslines - Open Cut | - | - | - | - | - | - |
| | - Bore and Case | - | - | - | - | - | - |
| .80 | Crossings - Railroad - Bore and Case | - | - | - | - | - | - |
| .81 | Crossings - Stream | - | - | - | - | - | - |
| .82 | Clean-up and Hydro-Seeding | - | - | 8.20/m | - | 21,240 | 21,240 |
| .86 | Drainage Pipelines | #8 - 500 m L.S. | - | - | 46,155 | 167,415 | 213,570 |
| .87 | Access Manholes | 1 L.S. | - | - | 9,200 | 2,000 | 11,200 |
| .88 | Pig Traps | 1 L.S. | - | - | 185,960 | 44,740 | 230,700 |
| .90 | Land Costs | - | 5.20/m | 0.21/m | 13,470 | 545 | 14,015 |
| | Total | - | - | - | - | - | 1,712,785 \$661.3/m |
| | Total-Rounded | - | - | - | - | - | 1,715,000 662.2/m |

(V4251/2, App. 1)

APPENDIX 2
ILLUSTRATIONS

PRELIMINARY DESIGN ROUTE
SANDWELL REPORT V 4191/1



- NOTES:
- TOPOGRAPHY IS BASED ON FOLLOWING MAPS:
 - 1. FROM THE SURVEY AND MAPS SERVICE OF THE B.C. LANDS SERVICE:
 - PLANNING MAPS TO BE 1/50,000, 1/50,000 AND 1/25,000, SCALE 1/50,000 AND 1/25,000.
 - COVERED AND DRAWN BY THE SURVEY SERVICE IN 1960, 1961, 1962, 1963, 1964, 1965, 1966, 1967, 1968, 1969, 1970, 1971, 1972, 1973, 1974, 1975, 1976, 1977, 1978, 1979, 1980, 1981, 1982, 1983, 1984, 1985, 1986, 1987, 1988, 1989, 1990, 1991, 1992, 1993, 1994, 1995, 1996, 1997, 1998, 1999, 2000, 2001, 2002, 2003, 2004, 2005, 2006, 2007, 2008, 2009, 2010, 2011, 2012, 2013, 2014, 2015, 2016, 2017, 2018, 2019, 2020.
 - FROM GEOLOGICAL SURVEY OF CANADA:
 - MAPS 1:50,000, 1:25,000 AND 1:10,000, SCALE 1:50,000, 1:25,000 AND 1:10,000.
 - INFORMATION AND PUBLISHED IN 1960 AND 1961.
 - CONTOUR LINES ARE IN FEET.

LEGEND

- BOUNDARY
- HEIGHT OF LAND
- TRANSMISSION LINE

1:50,000

| | |
|-------|-----------|
| DES | REC'D |
| OWN | SH |
| CHKD | A.C. |
| APP'D | R.C. |
| DATE | APRIL '78 |

SANDWELL DWS NO.
BRITISH COLUMBIA HYDRO AND POWER AUTHORITY

HAT CREEK PROJECT
COOLING WATER SUPPLY
BREAKDOWN OF COST ESTIMATE
PIPELINE ROUTE

SCALE AS SHOWN
DWS No B 4251/2-1

| | | | |
|--------------------|--------------------|-----------|-----------|
| REFERENCE DRAWINGS | REFERENCE DRAWINGS | REVISIONS | REVISIONS |
|--------------------|--------------------|-----------|-----------|

PROJECT MEMORANDUM V4251/3

WATER TREATMENT BY MEANS OF SETTLING

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PROJECT MEMORANDUM V4251/3
WATER TREATMENT BY MEANS OF SETTLING

DATE 25 AUGUST 1978

CONTENTS

| | |
|---|----|
| INTRODUCTION | 1 |
| PROPOSALS | 1 |
| THEORY OF SETTLING | 4 |
| APPLICATION OF SETTLING | 6 |
| CONCLUSIONS | 9 |
| DESIGN PARAMETERS | |
| General | 9 |
| Feedwell | 9 |
| Minimum Operating Temperature | 9 |
| Specific Gravity of Thompson River Solids | 9 |
| Minimum Settled Particle Size | 10 |
| Safety Factor | 10 |
| Summary of Design Parameter Recommendations | 11 |
| APPENDICES | |
| 1 - References | |
| 2 - Letter of Inquiry for Water Treatment dated 7 October 1977 | |
| 3 - Resumes of Proposals for Settling Systems | |
| 4 - Resumes of Rejected Proposals: Centrifugal Cleaners, Media Filters and Micro Filters | |
| 5 - Dorr-Oliver-Long Hydroseparators: Installation List and Data | |
| 6 - Illustrations | |
| A4251/3-1 - Settling Rate/Particle Diameter Curves | |
| A4251/3-2 - Kinematic Viscosity/Temperature Curve for Water | |
| A4251/3-3 - Clarifier Diameter/Particle Size and Temperature | |
| A4251/3-4 - Thompson River Hydrograph and Temperature/Time Curve | |

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PROJECT MEMORANDUM V4251/3
WATER TREATMENT BY MEANS OF SETTLING

DATE 25 AUGUST 1978

INTRODUCTION

The purpose of this Project Memorandum is to record and review water treatment proposals received during the Preliminary Design Study, Project V4191, and to recommend design parameters for a degritting clarifier. This method of treatment was selected by Sandwell in Report V4191/1 (Reference 1.1)*, to remove Thompson River water solids for the prevention of erosion in the high pressure pumps.

PROPOSALS

Water treatment proposals were received in answer to Sandwell's letter of inquiry, dated 7 October 1977, Appendix 2. To obtain the widest possible response from water treatment suppliers, this inquiry did not specify the type of treatment system except for excluding large settling basins and prohibiting the use of chemicals. Table 1 on page 2 lists the proposals.

* For references see Appendix 1.

Table 1 - Proposed Water Treatment Systems

| <u>Treatment System</u> | <u>Make or Name</u> | <u>Units Required</u> | <u>Supplier</u> |
|-------------------------------|---|-----------------------|-------------------------------------|
| <u>1. Settling</u> | | | |
| 1.1 | Hydroseparator | 1 | Dorr-Oliver-Long Ltd. |
| 1.2 | Degritting Clarifier | 1 | Envirotech Canada Ltd. |
| 1.3 | Aerated Degritter | 1 | Degremont-Infilco Ltd. |
| 1.4 | Detritor | 1 | Dorr-Oliver-Long Ltd. |
| 1.5 | Grit Collector | 1 | Rexnord (Canada) Ltd. |
| <u>2. Centrifugal Cleaner</u> | | | |
| 2.1 | FR Dorrclone | 6 | Dorr-Oliver-Long Ltd. |
| 2.2 | Desanding Dorrclone | 7 or 12 | Dorr-Oliver-Long Ltd. |
| 2.3 | Desanding Dorrclone | 5 | US Filter Fluid Systems Corporation |
| 2.4 | Celleco Cleaner | 2 | Bancroft Western Sales Limited |
| 2.5 | Smith and Loveless Model 30:2 Pista Grit Trap or Model 30:1 | 30:2 or 30:1 | Ecodyne Ltd. |
| <u>3. Media Filter</u> | | | |
| 3.1 | Neptune Microfloc Filter | 8 | Neptune Microfloc |
| 3.2 | Peacock Immedium Upflow Filter | Not Given | Peacock Brothers Ltd. |
| 3.3 | Graver Filter | 6 | Ecodyne Limited |
| 3.4 | Graver Monovalve Filter | 17 | Ecodyne Limited |
| <u>4. Micro Filter</u> | | | |
| 4.1 | Cuno Automatic Flo-Klean Filter | 2 | Peacock Brothers Ltd. |
| 4.2 | North Water Filter | 8 | H.D. Fowler Co. Ltd. |

The majority of particles anticipated in the proposed Thompson River intake would range from 2.5 mm, the gap between the wires of the travelling screens, to 0.1 mm (Reference 1.3, Table 4). Particle sizes acceptable to the booster pumps are in the order of 0.2 mm and smaller (Reference 1.2).

For the required river solids removal system to work properly and efficiently, it must be able to:

1. Remove solids ranging from 2.5 mm to at least 0.2 mm.
2. Absorb shock loadings and avoid blinding.
3. Minimize land requirements, energy, supervision, water waste and wear.

4. Operate continuously, even under freezing conditions.
5. Operate without chemicals and without treatment of waste prior to discharge.
6. Dispose of removed solids.
7. Have proven technology.
8. Operate without enhancing algal growth.

The settling proposals, System 1, are acceptable in principle since they satisfy the above requirements. These proposals are examined in depth in this Project Memorandum in order to establish specific design parameters for use during final design. Resumes of these proposals are given in Appendix 3.

All other proposals in Table 1, Systems 2, 3 and 4, were rejected for the following reasons:

- Centrifugal cleaners (System 2) waste approximately 10 percent of inflow water, require energy (a head of 3 to 15m), are subject to wear and are generally used for removing solids ranging from 500 to 3 microns. Not only from an operational viewpoint are centrifugal cleaners less attractive than a settling system such as a degritting clarifier, but also from capital cost considerations, as shown below:

Degritting Clarifier Capital Cost

Based on Preliminary Design Study, Report V4191/1, Volume 1, Appendix 5, Details of Cost Estimate, page 5, Item 273.64:

| | |
|----------------------------|----------------|
| Concrete vat, 30m diameter | \$ 75,000 |
| Rake, including erection | 170,000 |
| Dome, to prevent freezing | <u>105,000</u> |
| Total | \$350,000 |

Centrifugal Cleaning Capital Cost

Based on Dorr-Oliver-Long's telex proposal of 28 June 1978, for twelve 76cm (30 in.) diameter Desanding Dorrclone centrifugal cleaners with a pressure drop of 5.3m (7.5 psig), see Appendix 4, Item 2.2. A proposal in the same telex for 7 identical units but operating with a pressure drop of 14.1m (20 psig) was found to be less economical because of higher energy cost. Present value of energy cost was based on 35 years, 20 mills per Kwh, 8 percent interest, intake pump efficiency of 80 percent, and motor efficiency of 90 percent:

| | |
|--|----------------|
| 12 Dorrclones | \$144,000 |
| Taxes, piping, fittings and erection of Dorrclones | 108,000 |
| Housing | 50,000 |
| Increased capacity at intake (allowance) | 100,000 |
| Present value of energy | <u>112,000</u> |
| Total | \$514,000 |

- Media filters (System 3) would collect the majority of particles between 2.5mm and 0.1mm, but since they are cleaned by means of a reversed flow whereby only particles smaller than 0.5 to 0.1mm (depending on media sizes) can be back washed, most of the river solids would be trapped permanently. These solids could be back washed by increasing the reversed flow but this would also remove filter media - an unacceptable condition. A media filter is, therefore, not suitable in this application as it would gradually fill up with solids.
- Micro filters (System 4) are designed to operate at a high rate of 20 to 50 l/s per m² (30 to 70 USGPM per ft²) and are primarily used where solids concentrations are consistently low. Because of the danger of blinding in the case of Thompson River water, micro filters are not recommended.

Details of Systems 2, 3 and 4 are given in resumes contained in Appendix 4.

THEORY OF SETTLING

Data on the theory of settling were obtained from sources in Reference 2.

The rate of settling of a discrete particle in a fluid is a function of the viscosity, density and temperature of the fluid, of the size, shape, and specific gravity of the particle and of the Reynolds number.

Drawing A4251/3-1* shows the rate of settling in still water of 20°C, for particles varying from 10 microns to 1 cm and having specific gravities varying from 2.65 (discrete sand particles) to 1.05 (flocculated mud particles). Reynolds numbers differentiate three settling zones: the eddying resistance, the Stokes Law and the transition zone.

- The eddying resistance zone is for Reynolds numbers greater than 2000. This is the turbulent zone where eddying resistance slows the settling rate. As it applies to particles larger than 5mm, it is outside the range of particles considered here.

* For drawings, see Appendix 6 - Illustrations

- The Stokes Law is for Reynolds numbers less than 1. Particles in this zone are in a laminar flow region where viscous resistance from the water particles slows the settling rate, expressed as follows:

$$V = \frac{1}{18} \frac{g}{\eta} \left(\frac{S_p}{S_f} - 1 \right) \cdot d^2 \quad \text{(Stokes Law)}$$

in which V = settling rate in cm/s
 g = acceleration due to gravity in cm/s²
 η = kinematic viscosity of the fluid in cm²/s
 Sp = specific gravity of the particle
 Sf = specific gravity of the fluid
 d = diameter of the particle in cm

Viscosity is influenced by temperature. Thompson River water temperatures range from 0°C to 19.5°C at Spences Bridge, over the period of record commencing in 1952 (Reference 3). Drawing A4251/3-2 shows that, over this temperature range, the viscosity of water increases significantly, from 0.95 at 19.5°C to 1.65 at 0°C (Reference 4). As the settling rate varies inversely with the viscosity, this rate decreases with lower temperatures. Therefore, at 0°C it is 0.95/1.65 = 0.6 of that at 19.5°C. This illustrates the significant influence of temperature in the design of settling systems.

- The transition zone is for Reynolds numbers from 1 to 2000. This zone includes most of the particles relevant to the Hat Creek application.

A mathematical expression for the settling rate in this zone is not available and these rates are, therefore, based on experiments such as carried out by Hazen (Reference 2.1) for particles from 10 mm to 0.1 mm. Settling rates are listed in Table 2 (Reference 5), which also gives settling rates in the Stokes Law zone, for particles from 60 micron to 4 micron.

In addition to "Settling rate", Table 2 also lists "overflow rate". The former is expressed as length per unit time, whereas the latter is expressed as flow per unit area. Water treatment suppliers commonly use the overflow rate as it can be equated directly to a tank size.

Table 2 - Settling Rates

| Diameter of Particle | | Classification | Settling Rate | Overflow Rate or Rise Rate | | |
|----------------------|--------|----------------|---------------|----------------------------|--------------------|-----------------|
| Micron | mm | | | mm/s | l/s/m ² | |
| 600 | 10.0) | Gravel | 1 000 | 1 000 | 1 475 | Hazen ↑ ↓ |
| | 1.0) | | 100 | 100 | 148 | |
| | 0.6) | | 63 | 63 | 93 | |
| 400 | 0.4) | Coarse Sand | 42 | 42 | 62 | |
| 200 | 0.2) | | 21 | 21 | 31 | |
| 100 | 0.1) | | 8 | 8 | 11.8 | |
| 60 |) | | 3.8 | 3.8 | 5.6 | |
| 40 |) | Fine Sand | 2.1 | 2.1 | 3.1 | |
| 20 |) | | 0.62 | 0.62 | 0.91 | |
| 10 |) | | 0.154 | 0.154 | 0.227 | |
| 4 |) | Silt | 0.025 | 0.025 | 0.036 | Stokes ↓ |

Note: These settling rates are in still water of 10°C for discrete particles with a specific gravity of 2.65

The settling rates in Table 2 apply to discrete particles with a specific gravity of 2.65. This is for sand and silt as given in Reference 5. For soil in general, the specific gravity varies from 2.0 to 3.0, however it is usually between 2.6 and 2.7 (Reference 6).

APPLICATION OF SETTLING

To evaluate the proposed settling systems listed in Table 1, installation lists were obtained from suppliers. In addition, overflow rates were established based on 1580 l/s (25,000 USGPM), the flow given in the letter of inquiry. These overflow rates together with other system parameters are given in Table 3.

Table 3 - Comparison of Parameters of Proposed Settling Systems
System Number and Supplier

| <u>Item</u> | | 1.1 Dorr-Oliver <u>-Long</u> | 1.2 <u>Envirotech</u> | 1.3 <u>Degremont-Infilco</u> | 1.4 Dorr-Oliver <u>-Long-</u> | 1.5 <u>Rexnord</u> |
|--------------------------------------|-------------------------|------------------------------------|--------------------------|---------------------------------|-------------------------------------|-----------------------|
| Name | | Hydroseparator | Degritting Clarifier | Aerated Degritter | Detritor | Grit Collector |
| Tank Size | - m | 24 diameter | 29 diameter | 10 x 16 | 12 diameter | 5 x 21 |
| | - ft | 80 diameter | 95 diameter | 33 x 52 | 40 diameter | 15 x 70 |
| Tank Area | - m ² | 430 | 540 | 140 | 120 | 100 |
| excluding feedwell | - ft ² | 4640 | 5830 | 1450 | 1260 | 1050 |
| Minimum Operating Temperature | - °C | 2 | 0 | Not given | Not given | Not given |
| Specific Gravity of Settled Particle | | 2.65 | 2.65 | Not given | Not given | Not given |
| Safety Factor | | 1.43 | 2 | 1 | 1 | 1 |
| Overflow Rate | - l/s/m ² | 3.6 | 2.9 | 11.7 | 13.5 | 16.1 |
| after applying safety factor | - USGPM/ft ² | 5.4 | 4.3 | 17.2 | 19.9 | 23.8 |
| Minimum Settled Particle Size | - Microns | 100 | 100 | 200 | 150 | 200 |

Note: Data in this table are based on an inflow of 1580 l/s (25,000 USGPM).

The safety factor is an important system parameter. It allows for discrepancies between actual and theoretical overflow rates, because of actual particle densities, turbulence, wind action, short circuiting, thermal currents and flocculating effects.

The diversity of overflow rates, safety factors and minimum particle size used by water treatment suppliers indicates that final design inquiries should be based on specific parameters.

Of the five proposed settling systems listed in Table 3, following are the two which satisfy the requirements for the Hat Creek Project.

Hydroseparator By Dorr-Oliver-Long (1.1)

This separator is a circular clarifier with rake mechanism and operates without the addition of chemicals in many industrial plants to recover solids.

Design is based on Table 2, adjusted for minimum operating temperature and safety factor. Dorr-Oliver-Long lists 24 installations, five in Canada and the balance in the USA. For details see Appendix 5.

Degritting Clarifier by Envirotech Canada Limited (1.2)

This circular clarifier with rake mechanism is custom designed on the basis of Table 2, adjusted for minimum operating temperature and safety factor. Although not backed up by installations, this system is acceptable as it is similar to Dorr-Oliver-Long's Hydroseparator.

The other proposed settling systems, 1.3, 1.4 and 1.5, would be unsuitable for the Hat Creek Project, because these systems do not apply to raw water, as elaborated below.

Aerated Degritter by Degremont-Infilco (1.3)

This aerated degritter is only used in sewage treatment plants, where entrained air aids the separation of organic material from sand particles. Although Degremont-Infilco claimed that entrained air would also be of value in raw water degritting, experience records to substantiate this were not provided.

Detritor by Dorr-Oliver-Long (1.4)

The Detritor is similar to a circular clarifier with rake mechanism, except that the liquid flows across the clarifier rather than from the centre. The Detritor is commonly used for degritting sewage, prior to treatment (Reference 7). Subsequent to Sandwell's request for installations on raw river water, Dorr-Oliver-Long withdrew the Detritor in favour of their Hydroseparator.

Grit Collector by Bexnord (1.5)

This system consists of a rectangular settling tank with a V-bottom. Solids collected in the bottom are removed by means of a pump mounted on a travelling bridge. Its main application appears for sludge removal in water and waste treatment plants. Applications for the treatment of raw water were not supplied.

CONCLUSIONS

On the basis of both theory and application of settling it can be concluded that:

1. A clarifier provides a reliable method for the removal of Thompson River water solids by means of settling.
2. Clarifier design can be based on overflow rates given in Table 2, provided these are adjusted for temperature, safety factor and, if necessary, specific gravity of particle.

DESIGN PARAMETERS

General

Drawing A4251/3-3, prepared on the basis of overflow rates in Table 2, shows the relationship between minimum settled particle size and clarifier diameter at 0°C and 20°C, with a safety factor of 2 and for a capacity of 1,660 l/s. This capacity is 5 percent more than the cooling water supply design capacity of 1,580 l/s, to allow for clarifier underflow and process losses. On the basis of this drawing the following design parameters are discussed.

Feedwell

Although the feedwell adds considerably to the overall clarifier diameter, it is important that it be large enough to avoid high entrance velocities into the clarifier. The assumed diameter of 12 m would provide a weir rate of 44 l/s.

Minimum Operating Temperature

A clarifier designed to remove particles down to 200 microns would have a diameter of 17.5 m at 20°C, and 20.5 m at 0°C, an increase of 17 percent. Similarly for 100 microns, 23.5 m at 20°C and 30 m at 0°C, an increase of 28 percent. Therefore, there would be significant savings if a higher design temperature than 0°C could be selected. This, however, is not recommended as the most critical condition occurs in winter when water temperatures are 0°C and suspended solids can be present in the intake due to its proximity to the eroding Ashcroft bluffs (Reference 1.4).

Drawing A4251/3-4 shows the relationship between a typical Thompson River hydrograph and the river water temperature curve, both at Spences Bridge. This indicates that the freshet peaks when the river water temperature is only 14°C, 6 degrees below its maximum of 20°C. Although the freshet peak may give the highest solids concentration in the river, reliable solids removal must already take place when solids first appear in the river. This occurs when the river starts to rise in April when water temperatures are approximately 2 to 4°C. As protection of the high pressures pumps is the sole objective of the clarifier, it is recommended that it be provided all year round and, therefore, that 0°C be selected as the minimum operating temperature.

Specific Gravity of Thompson River Solids

Overflow rates in Table 2 are based on sand and silt particles; these have a specific gravity of 2.65. For the purpose of comparison, specific gravities for materials similar to sand and silt and for organic and mud particles are given in Table 4.

Table 4 - Specific Gravities

| <u>Material</u> | <u>Amount</u> |
|-----------------------------|---------------|
| Mica | 2.8 |
| Granite | 2.7 |
| Shale, Limestone and Quartz | 2.6 |
| Asbestos and Gypsum | 2.4 |
| Sandstone | 2.3 |
| Concrete | 2.2 |
| Suspended organic matter | 1.0-1.4 |
| Flocculated mud particles | 1.05 |

Water treatment handbooks, Dorr-Oliver-Long and Envirotech all use 2.65 as the specific gravity for river solids. It appears reasonable to assume that this same value can be used for Thompson River solids, because:

- Thompson River solids settle in the sump of the municipal intake at Ashcroft (Reference 8).
- Ashcroft municipal water is not treated which is indicative of the absence of lightweight particles.
- Specific gravities of materials similar to sand and silt, listed in Table 4, are in the 2.65 ranges.

Therefore, it is recommended that 2.65 be used as the specific gravity for Thompson River solids, but that this value be confirmed during final design, on the basis of laboratory analyses.

Minimum Settled Particle Size

A clarifier operating at 0°C would require a diameter of 20.5 m for a minimum particle size removal of 200 microns, and 30 m for that of 100 microns, an increase of 46 percent. From a pump protection point of view, report V4191/1 recommends a minimum particle size removal of only 200 microns (Reference 1.3), whereas the clarifier recommended in this same report is for 100 microns with a diameter of 30 m. This conservative approach was followed for two reasons:

- To provide the best possible protection which can be obtained by means of a degritting clarifier at reasonable cost.
- To assure that the pump manufacturer will not be able to use water quality as an excuse to revoke his performance guarantee, in the event of failure of performance.

For final design, it is recommended that the minimum settled particle size be confirmed based on requirements for the selected equipment and a cost benefit study for clarifier diameters of 30 m and 20.5 m.

Safety Factor

The safety factor allows for discrepancies between actual and theoretical overflow rates. A factor of 2 is recommended.

Summary of Design Parameter Recommendations

Overflow Rate : Use Table 2, adjusted for temperature.

Feedwell : To be sized for a low clarifier entrance velocity.


Minimum Operating Temperature : 0°C

Specific Gravity of Settled Particle : 2.65. To be confirmed in Final Design.


Minimum Settled Particle Size : At least 200 microns, preferably 100 microns. To be confirmed in final design on the basis of pump requirements and cost benefit study.

Safety Factor : 2

Prepared by:


J. W. C. Boyle

Approved by:


A. Copeland, P. Eng.

APPENDIX 1

REFERENCES

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PROJECT MEMORANDUM V4251/3
WATER TREATMENT BY MEANS OF SETTLING

DATE 25 AUGUST 1978

APPENDIX 1 - REFERENCES

1. Sandwell and Company Limited, Report V4191/1, Hat Creek Project, Cooling Water Supply, Preliminary Design Study. Report to B.C. Hydro and Power Authority, March 1978
 - 1.1 Volume 1, p. 23.
 - 1.2 Volume 1, p. 30.
 - 1.3 Volume 2, Appendix 8, Project Memorandum V4191/5, Water Treatment, p.3.
 - 1.4 Volume 2, Appendix 8, Project Memorandum V4191/5, Water Treatment, p.2.
2. Theory of Settling.
 - 2.1 Allen Hazen, "On Sedimentation", American Society of Civil Engineers, paper no. 980, 1 June 1904.
 - 2.2 Skeat and Dangerfield, "Manual of British Water Engineering Practice, Volume III, Water Quality and Treatment", pp. 208 to 211.
 - 2.3 Tebbutt, "Principles of Water Quality Control", pp. 82 to 90.
 - 2.4 Fair, Geyer and Okun, "Water and Waste Water Engineering", pp. 25.2 to 25.5.
 - 2.5 Linsley and Franzini, "Water Resources Engineering", pp. 444 to 445.
3. Environment Canada "Water Temperatures, British Columbia and the Yukon Territories", Volume 4, 1977.
4. Data on Viscosity of Water.
 - 4.1 American Water Works Association, "Water Treatment Plant Design", p. 90.
 - 4.2 Perry, Chilton and Kirkpatrick, "Perry's Chemical Engineers' Handbook", p. 3.201.
 - 4.3 Davis, "Handbook of Applied Hydraulics", p. 960.


5. American Water Works Association, "Water Treatment Plant Design", p.91, Table 2.
6. P. N. Khanna, "Soil Mechanics", p. 6/9.
7. Solids removal.
 - 8.1 Dorr-Oliver-Long "Detritor", bulletin No. 64411C.
 - 8.2 The Institute of Water Pollution Control U.K., "Preliminary Processes", pp. 26 to 31.
8. Sandwell and Company Limited, "Field Visit Report V4191, Hat Creek Project, Cooling Water Supply, Ashcroft Pumping Station", Report of 13 June 1977.

APPENDIX 2

LETTER OF INQUIRY FOR WATER TREATMENT, DATED 7 OCTOBER 1977

Copies of this letter also sent to the following:

Envirotech Canada Ltd., Mimco Division,
Calgary, Alberta
Passavant, Vancouver, B.C.
Permutit, Vancouver, B.C.
Crane Cochrane, North Vancouver, B.C.
Peacock Brothers Ltd., Vancouver, B.C.
Neptune Microfloc, Calgary, Alberta
Degremont (Canada) Limited, Montreal, P.Q.
Dorr-Oliver-Long Limited, Vancouver, B.C.
Graver Water Div. of Ecodyne,
Oakville, Ontario



SANDWELL AND COMPANY LIMITED
SUITE 601 — 1550 ALBERNI STREET, VANCOUVER
B.C., CANADA V6G 1A4
TELEPHONE: 684-8151 AREA CODE: 604
CABLE ADDRESS: SANCCO.SULT • TELEX: 04 508738

7 October 1977

Rexnord (Canada) Ltd.
1955 West Broadway
Vancouver, B.C.

Attention: Sales Manager

Reference: V4191 B.C. Hydro and Power Authority
273.60 Pumping Station - Water Treatment

Dear Sir:

B. C. Hydro and Power Authority are planning a 2000 MW coal-fired generating station to utilize the coal deposits of the Hat Creek Valley, near the town of Ashcroft, in the Province of British Columbia, Canada. Our firm has been retained for the preliminary design of the cooling water make-up system for this project.

Introduction

The design capacity of the make-up system will be 1580 l/s (25,000 USGPM), which will be drawn from the Thompson River by means of a direct intake in the vicinity of Ashcroft, B.C.

The intake structure will house vertical travelling screens with a maximum mesh size of 2.5 mm (0.1 inch), and five low head vertical turbine pumps. These pumps will pass raw river water to a grit removal plant, after which four high pressure pumps will pump to a second stage high pressure station. From there, the water will be pumped to the plant reservoir in the Hat Creek Valley. The total head from the treatment plant to the plant reservoir will be 1255 m (4115 ft).

SANDWELL AND COMPANY LIMITED

V4191, 273.60, Rexnord (Canada) Ltd., 7 October 1977

Budget Proposal

To assist us in obtaining technical input and a budget price for this project, we request you to submit a preliminary proposal with budget prices, on a system to take out grit, in order to prevent wear on the costly high pressure pumps. The system will require to operate all year round in view of the chance of high solids loading from eroding cliffs nearby (see section on water quality for further details). A settling basin cannot be considered for the degritting system due to real estate restrictions, and because a dome will be required over the unit to prevent it from freezing, (since allowance will have to be made for intermittent pumping to suit electrical load requirements).

Background

We enclose some data on several characteristics of the Thompson River to enable you to decide on the optimum type of grit removal mechanism which you would propose for this project.

1. Water Quality Summary

The data presented in Appendix 1 was obtained from B. C. Hydro and was collected at Savona, approximately 32 kilometers (20 miles) upstream of Ashcroft.

Although the suspended solids load in the vicinity of the proposed intake is not known, we would expect it to be much higher than the maximum value of 7.6 mg/l indicated in the table in this Appendix. The reason for this is the presence of the Ashcroft Cliffs, which are upstream of the intake site. The erosion of these cliffs introduces solids all year round. This introduction is expected to be at its highest during the freshet when rising water elevations erode recent shore deposits from slides. Further introduction of solids takes place all year round when minor slides fall into the river.

2. Solids from Thompson River Bank

On 15 June 1977, a solids sample was taken from a bar on the left river bank opposite the Ashcroft Cliffs. Sieve analysis on this sample was carried out only on particles passing No. 8 sieve, 2.36 mm (0.93 inch). This sieve approximates most closely the maximum particle size which will pass the proposed intake travelling screens with stipulated maximum mesh opening of 2.5 mm (0.10 inch). The sieve analysis curve is shown in Figure 1, Appendix 2.

SANDWELL AND COMPANY LIMITED

V4191, 273.60, Rexnord (Canada) Ltd., 7 October 1977

3. Solids from Ashcroft Municipal Intake

The Municipality of Ashcroft operates an intake on the left bank of the Thompson River just downstream of the road bridge and 4 km (2.5 miles) downstream of the Ashcroft Cliffs. The intake consists of a pump well which is connected to the river by means of a 0.30 m (1 ft) diameter buried pipe which protrudes approximately 0.9 m (3 ft) above the river bottom; the entrance to this pipe is protected with a 40 mm (1.5 inch) square mesh screen. Apart from some chlorination no other treatment is given to this potable water supply.

As some river solids collect in the bottom of the pump well, Sandwell obtained 12 samples from different locations in the well and sieve analyses were carried out on sample numbers 2 and 10. These sieve analyses were only carried out on particles passing No. 8 sieve, 2.36 mm (0.93 inch). This sieve approximates most closely the maximum particle size which will pass the proposed intake travelling screens with stipulated maximum mesh opening of 2.5 mm (0.10 inch). For sieve curves see Figure 2 and 3, Appendix 2.

Sieve Analysis Results

The data presented in the table below has been abstracted from the sieve analyses of samples 1, 2 and 10.

Thompson River Solid
Particle Size Distribution in % of Dry Weight

| <u>Particle Size</u> | | <u>Origin of Sample</u> | | |
|----------------------|-------------|-------------------------|------------------------|-------------------|
| <u>mm</u> | <u>inch</u> | <u>River Bar</u> | <u>Ashcroft Intake</u> | |
| | | <u>Sample #1</u> | <u>Sample #2</u> | <u>Sample #10</u> |
| 2.36 - 1.00 | .093 - .039 | 20 | 27 | 20 |
| 1.00 - 0.50 | .039 - .020 | 34 | 31 | 46 |
| 0.50 - 0.30 | .020 - .012 | 29 | 26 | 24 |
| 0.30 - 0.10 | .012 - .004 | 14 | 14 | 9 |
| < 0.10 | < .004 | 3 | 2 | 1 |
| 2.36 - 0.30 | .093 - .012 | 83 | 84 | 90 |
| 0.30 - 0.10 | .093 - .004 | 14 | 14 | 9 |
| < 0.10 | < .004 | 3 | 2 | 1 |

SANDWELL AND COMPANY LIMITED

V4191, 273.60, Rexnord (Canada) Ltd., 7 October 1977

4. Solids Anticipated in Proposed Hat Creek Intake

The proposed Hat Creek intake would withdraw water directly from the river before solids have had a chance to settle out and from a zone rich in suspended solids. Although this zone of water withdrawal would on the average be less deep than that of the Ashcroft intake, it is considered very unlikely that the size distribution of particles smaller than 2.5 mm (0.10 inch) to be anticipated in the Hat Creek intake would be much different than those found in the Ashcroft intake. It is interesting to note the striking resemblance between the size distribution of the sieve analysis of the sample taken near the Ashcroft Cliffs and those taken from the Ashcroft intake well (distance between sampling points is approximately 4 kilometers (2.5 miles).

5. Algae

Some data is included for your information in Appendix 3 on algal growth in the Thompson River.

Degritting System

We request you to submit typical arrangement drawings indicating the method(s) which you would propose to remove grit from the raw water, together with budget costs for the structures (excluding housings) and mechanical plant. Delivery should be quoted on an F.O.B. plant price, together with the plant weight and the place where it will be transported from. The system can be designed such that the grit can be returned to the river. We emphasize that the only objective of this system is to remove solids from the flow to prevent pump impeller wear. Although we do not know the anticipated solids concentration in the river, your system must be conservatively designed to cope with, at times, concentrations of at least 100 - 500 mg/l; the anticipated minimum particle size that your system will be capable of removing must be given, (chemical addition must not be considered, so that waste can be returned to the river without causing environmental concern). Details of completed projects of similar installations which process raw water without the addition of chemicals are required together with all predicted head and water losses associated with your proposed system. The desirability of pilot plant studies should be indicated.

SANDWELL AND COMPANY LIMITED

V4191, 273.60, Rexnord (Canada) Ltd., 7 October 1977

Filters

Once the degritting system is in operation, experience could indicate that this system alone would not be adequate to prevent wear on the pump impellers and an additional gravity filter system would then be required to further remove solids. We therefore also request your proposal for such a filter (no cost estimates are necessary), and to what extent this filter would be able to remove solids carried over from the degritting system. The only objective for the gravity filter would be to remove solids to prevent pump impeller wear. Back wash water would be returned to the river and, therefore, chemical addition would not be allowed in this process. All predicted head and water losses are required as are examples of similar installations that remove solids without the addition of chemicals. The desirability of pilot plant studies should be indicated.

Shock Loading

Because of the anticipated intensities of river solids concentrations, the degritting system and filters shall have a high capacity to absorb shock loadings. Systems which could become blinded, such as micro screens and micro strainers, are, therefore, considered undesirable.


Alternatives

In addition to supplying us the information requested in this letter, we would welcome any alternative proposals which you may wish to present.

Should you have any questions on the contents of this letter do not hesitate to contact the undersigned. We would appreciate your proposal being submitted on or before the 4th of November 1977.

Yours truly

SANDWELL AND COMPANY LIMITED


A. Copeland, P.Eng.

JWCB/vw

Attachments

cc: Mr. C. K. Harman, B. C. Hydro, Vancouver

bcc: A. Copeland

J. Boyle

APPENDIX 1
WATER QUALITY DATA

APPENDIX 1 - WATER QUALITY DATATHOMPSON RIVER (SAVONA) WATER QUALITY SUMMARY

| <u>PARAMETER</u> ⁽¹⁾ | <u>AVERAGE</u> ⁻⁻ | <u>MAXIMUM</u> |
|--|------------------------------|----------------|
| Total Dissolved Solids ⁽²⁾ | 57.4 | 72.0 |
| Total Solids ⁽²⁾ | 60.4 | 74.0 |
| Suspended Solids ⁽²⁾ | 3.1 | 7.6 |
| Turbidity (JTU) ⁽²⁾ | 1.8 | 8.5 |
| Specific Conductance ($\mu\text{mho/cm}$) ⁽²⁾ | 98 | 225 |
| Oil & Grease ⁽²⁾ | < 1.0 | 2.0 |
| pH (units) ⁽²⁾ | 7.5 | 8.6 |
| Alkalinity (CaCO_3) ⁽²⁾ | 35.1 | 44.8 |
| Hardness (CaCO_3) ⁽²⁾ | 38.2 | 47.6 |
| Calcium (dissolved) ⁽²⁾ | 12.1 | 14.6 |
| Magnesium (dissolved) ⁽²⁾ | 1.9 | 2.6 |
| Chloride ⁽²⁾ | 1.5 | 3.1 |
| Sulphate ⁽²⁾ | 7.2 | 10.0 |
| Silica ⁽²⁾ (as SiO_2) | 4.8 | 6.5 |
| Colloidal Silica | -- | 2.1 |
| Nitrate-Nitrogen ⁽²⁾ | 0.09 | 0.22 |
| Nitrite-Nitrogen | < 0.005 | < 0.005 |
| Ammonia-Nitrogen | 0.012 | 0.03 |
| Total Kjeldahl Nitrogen | 0.1 | 0.24 |
| Nitrogen, Organic | 0.08 | 0.15 |
| Phosphorous as P ⁽²⁾ | 0.007 | 0.021 |
| Organic Carbon ⁽²⁾ | 3.12 | 10.0 |
| Inorganic Carbon ⁽²⁾ | 7.4 | 10.0 |
| Phenol | 0.002 | 0.003 |

THOMPSON RIVER (SAVONA) WATER QUALITY SUMMARY

| <u>PARAMETER</u> ⁽¹⁾ | <u>AVERAGE</u> | <u>MAXIMUM</u> |
|---------------------------------|----------------|----------------|
| Arsenic, Dissolved | < 0.005 | < 0.005 |
| Chromium, Dissolved | < 0.005 | < 0.005 |
| Chromium, Total | < 0.005 | < 0.005 |
| Copper, Dissolved | < 0.006 | 0.06 |
| Iron, Dissolved | < 0.09 | 0.10 |
| Lead, Dissolved | < 0.0015 | < 0.003 |
| Lead, Total | < 0.0019 | < 0.003 |
| Mercury, Total (µg/l) | < 0.05 | 0.25 |
| Manganese, Total | < 0.01 | 0.01 |
| Molybdenum, Dissolved (µg/l) | < 0.5 | 0.7 |
| Potassium | 0.85 | 0.9 |
| Sodium | 2.24 | 3.2 |
| Zinc, Dissolved | 0.02 | 0.12 |


Notes:

1. All parameters expressed in mg/l unless otherwise noted.
2. Average values represent monthly annual averages, all other parameters represent total sample averages.

APPENDIX 2

SIEVE ANALYSIS CURVES

M.I.T. GRAIN SIZE SCALE




Goldier Associates

GRAIN SIZE DISTRIBUTION
HAT CREEK WATER SUPPLY
THOMPSON RIVER

Figure 1.

| | | | | | | | | | | |
|---------|-------------|-------------|--------|------|-----------|--------|------|--------------|--|-----------|
| BOULDER | COBBLE SIZE | COARSE | MEDIUM | FINE | COARSE | MEDIUM | FINE | SILT SIZE | | CLAY SIZE |
| | | GRAVEL SIZE | | | SAND SIZE | | | FINE GRAINED | | |

M.I.T. GRAIN SIZE SCALE




Goldier Associates

GRAIN SIZE DISTRIBUTION
HAT CREEK WATER SUPPLY
THOMPSON RIVER

Figure 2.

| | | | | | | | | | |
|---------|----------------|-------------|--------|------|-----------|--------|------|-----------|-----------|
| BOULDER | COBBLE SIZE | COARSE | MEDIUM | FINE | COARSE | MEDIUM | FINE | SILT SIZE | CLAY SIZE |
| | | GRAVEL SIZE | | | SAND SIZE | | | | |

M.I.T. GRAIN SIZE SCALE



GRAIN SIZE DISTRIBUTION
HAT CREEK WATER SUPPLY
THOMPSON RIVER

Figure 15.

Goldier Associates

| | | | | | | | | | | |
|---------|----------------|-------------|--------|------|-----------|--------|------|--------------|--|-----------|
| BOULDER | COBBLE SIZE | COARSE | MEDIUM | FINE | COARSE | MEDIUM | FINE | SILT SIZE | | CLAY SIZE |
| | | GRAVEL SIZE | | | SAND SIZE | | | FINE GRAINED | | |

APPENDIX 3

ALGAL GROWTH IN THE THOMPSON RIVER

APPENDIX 3 - ALGAL GROWTH IN THE THOMPSON RIVER

ALGAE

Tables 1,2, and 3 (attached) summarize phytoplankton data for three sample periods at the Walachin Bridge, 23 February, 17 March and 2 June, 1977, 22 kilometers (14 miles) upstream of Ashcroft.

Phytoplankton densities increased from 262,871 to 383,332 to 695,265 units per litre over the sampling period. It is considered that maximum productivity will not be achieved in the Thompson River system until late August.

The data from this program indicated a preponderance of diatom species within each sample. Servici (1976) and BEAK (1973) have similarly indicated a dominance of diatoms in periphyton samples collected in the Thompson system and the Pollution Control Branch and Environment Canada (1973) also indicated a dominating effect of diatoms on the south Thompson system near Walachin. Diatoms generally range in size from 5 μ to 75 μ .

Langer and Nassichuk (1975) indicated that there exists a proliferation of periphytic algae downstream of Kamloops Lake due to nutrient input from domestic and industrial discharges into the system. Langer and Nassichuk (1975) also indicated that with the water currents found in the Thompson River, periphytic filamentous growths may become dislodged and form mat-like rafts of algae. They also speculate that this phenomenon occurs relatively frequently.

In summary, it is evident that those algal groups prevalent within the phytoplankton community of the Thompson River near Walachin are comparable to the periphytic associations reported in other studies. A dominant group within these two life systems were the diatom species. The most significant factors in terms of an intake structure would be diatoms, which appear to achieve maximum concentration in August, and upstream periphytic colonies that exhibit a potential to dislodge in large mats.

APPENDIX 4

COMPUTER PRINT OUT OF
PHYTOPLANKTON DATA FROM THE
THOMPSON RIVER STUDY

TABLE 1: PHYTOPLANKTON DATA
THOMPSON RIVER STUDY

DATE: 23 FEBRUARY 1977

| TAXA | UNITS/LITER | % |
|---------------------------------|-------------|------|
| RHODOMONAS MINUTA | 53519 | 20.4 |
| CHLORELLA-LIKE #1 | 41686 | 15.9 |
| ACNANTHES MINUTISSIMA | 35032 | 13.3 |
| SYNEDRA VAUCHERIAE | 20987 | 8.0 |
| ACNANTHES LINEARIS | 13569 | 5.2 |
| GOMPHONEMA OLIVACEOIDES | 12701 | 4.8 |
| RHODOMONAS LACUSTRIS | 12224 | 4.7 |
| TABELLARIA FENESTRATA | 10558 | 4.0 |
| FRAGILARIA CROTONENSIS | 6542 | 2.5 |
| CYCLOTELLA STELLIGERA | 5249 | 2.0 |
| CYMBELLA MINUTA | 4798 | 1.8 |
| ASTERIONELLA FORMOSA | 3973 | 1.5 |
| CRYPTOMONAS OVATA | 3514 | 1.3 |
| TETRASELMIS #1 | 2203 | .8 |
| RHIZOLENIA ERIENSIS | 2195 | .8 |
| GOMPHONEMA DICHOTOMUM | 2195 | .8 |
| STEPHANODISCUS ASTRAEA | 2186 | .8 |
| ARTHROSPIRA JENNERI | 2178 | .8 |
| FRAGILARIA CONSTRUENS | 1761 | .7 |
| AMPHORA PERPUSILLA | 1752 | .7 |
| CHRYSOPHYTE STATOSPORE #11 | 1752 | .7 |
| NAVICULA CRYPTOCEPHALA V. VENET | 1744 | .7 |
| MELOSIRA DISTANS V. ALPIGENA | 1735 | .7 |
| GOMPHONEMA SUBCLAVATUM | 1319 | .5 |
| NITZSCHIA RECTA | 885 | .3 |
| ACNANTHES LANCEOLATA | 885 | .3 |
| NITZSCHIA SILICA | 885 | .3 |
| TREUBARIA TRIAPPENDICULATA | 885 | .3 |
| CYCLOTELLA KUTZINGIANA | 876 | .3 |
| SCENEDEDMUS DENTICULATUS | 876 | .3 |
| MELOSIRA ITALICA | 868 | .3 |
| OCHROMONAS-LIKE | 868 | .3 |
| DIATOMA TENUE | 868 | .3 |
| NITZSCHIA FRUSTULUM | 868 | .3 |
| STEPHANODISCUS ASTRAEA V. MIN | 442 | .2 |
| NITZSCHIA LINEARIS | 442 | .2 |
| NITZSCHIA GRACILIS | 442 | .2 |
| HANNAEA ARCUS | 442 | .2 |
| CHROMULINA-LIKE | 442 | .2 |

TABLE 1: PHYTOPLANKTON DATA (CONTINUED)

| TAXA | STATION 346 | |
|--------------------------------------|-------------|----|
| | UNITS/LITER | % |
| ULOTHRIX ZONATA | 442 | .2 |
| CALONEIS HYALINA | 442 | .2 |
| COSCINODISCUS ROTHII | 434 | .2 |
| NITZSCHIA ACICULARIS | 434 | .2 |
| NAVICULA #13 | 434 | .2 |
| CYMBELLA CISTULA | 434 | .2 |
| NAVICULA MINIMA | 434 | .2 |
| ACNANTHES HAUCKIANA | 434 | .2 |
| ACNANTHES PERGALLI | 434 | .2 |
| CYMBELLA SINUATA | 434 | .2 |
| NITZSCHIA DISSIPATA | 434 | .2 |
| SYNEDRA DELICATISSIMA | 434 | .2 |
| NITZSCHIA PALEA | 434 | .2 |
| CYMBELLA AFFINIS | 434 | .2 |
| CHLAMYDOMONAS-LIKE | 434 | .2 |
| TOTAL MEAN DENSITY (UNITS/LITER) | 262871 | |
| STANDARD ERROR OF MEAN DENSITY | 2576 | |
| COEFF. OF VARIATION OF REPLICATES(%) | 1.39 | |
| TOTAL TAXA/STATION | 54 | |
| MEAN UNITS COUNTED/REPLICATE | 300.00 | |
| NUMBER OF REPLICATES | 2 | |

**** = LESS THAN .1%

TABLE 2: PHYTOPLANKTON DATA
THOMPSON RIVER STUDY

DATE: 17 MARCH

1977

| TAXA | UNITS/LITER | % |
|-------------------------|-------------|------|
| ACNANTHES MINUTISSIMA | 98039 | 25.6 |
| CHLORELLA-LIKE #1 | 46023 | 12.0 |
| SYNEDRA VAUCHERIAE | 45567 | 11.9 |
| GOMPHONEMA OLIVACEOIDES | 30818 | 8.0 |
| RHODOMONAS MINUTA | 27375 | 7.1 |
| CYMBELLA MINUTA | 17304 | 4.5 |
| HANNAEA ARCUS | 13666 | 3.6 |
| RHODOMONAS LACUSTRIS | 11153 | 2.9 |
| ACNANTHES LINEARIS | 10612 | 2.8 |
| NITZSCHIA RECTA | 5458 | 1.4 |
| ASTERIONELLA FORMOSA | 5068 | 1.3 |
| CHLAMYDOMONAS-LIKE | 4721 | 1.2 |
| CYCLOTELLA KUTZINGIANA | 4028 | 1.1 |
| SYNEDRA RUMPENS | 4028 | 1.1 |
| NITZSCHIA PALEA | 3682 | 1.0 |
| GOMPHONEMA OLIVACEUM | 3444 | .9 |
| CYCLOTELLA STELLIGERA | 3292 | .9 |
| TABELLARIA FENESTRATA | 3097 | .8 |
| FRAGILARIA CROTONENSIS | 2945 | .8 |
| TETRASELMIS #1 | 2902 | .8 |
| GOMPHONEMA SUBCLAVATUM | 2902 | .8 |
| CYMBELLA AFFINIS | 2556 | .7 |
| OCHROMONAS-LIKE | 2209 | .6 |
| CYMBELLA CISTULA | 2209 | .6 |
| NITZSCHIA FRUSTULUM | 2014 | .5 |
| NITZSCHIA ACICULARIS | 2014 | .5 |
| GOMPHONEMA HEDINII | 1819 | .5 |
| NITZSCHIA SILICA | 1819 | .5 |
| FRAGILARIA LEPTOSTAURON | 1624 | .4 |
| MELOSIRA ITALICA | 1473 | .4 |
| CHROOMONAS NORDSTEDII | 1473 | .4 |
| CRYPTOMONAS OVATA | 1278 | .3 |
| SYNEDRA RADIANS | 1278 | .3 |
| ARTHROSPIRA JENNERI | 1278 | .3 |
| AULOMONAS PURDYI | 1083 | .3 |
| RHIZOLENIA ERIENSIS | 1083 | .3 |
| DIATOMA VULGARE | 1083 | .3 |
| NITZSCHIA BREVIROSTRIS | 736 | .2 |
| ACNANTHES FLEXELLA | 736 | .2 |

TABLE 2: PHYTOPLANKTON DATA (CONTINUED)

| TAXA | STATION 401 | |
|---------------------------------------|-------------|----|
| | UNITS/LITER | % |
| SCENEDESMUS DENTICULATUS | 736 | .2 |
| AMPHIPLEURA PELLUCIDA | 736 | .2 |
| OSCILLATORIA LIMNETICA | 736 | .2 |
| FRAGILARIA CONSTRUENS | 736 | .2 |
| ANKISTRODESMUS FALCATUS | 541 | .1 |
| NITZSCHIA SUBACICULARIS | 541 | .1 |
| CHROMULINA-LIKE | 541 | .1 |
| STAURONEIS ANCEPS | 541 | .1 |
| NITZSCHIA FONTICOLA | 541 | .1 |
| NITZSCHIA DISSIPATA | 541 | .1 |
| TREUBARIA TRIAPPENDICULATA | 541 | .1 |
| NITZSCHIA LINEARIS | 541 | .1 |
| SYNEDRA MAZAMAENSIS | 541 | .1 |
| ACNANTHES LANCEOLATA | 541 | .1 |
| SYNEDRA ULNA | 541 | .1 |
| GOMPHONEMA PARVULUM | 541 | .1 |
| TOTAL MEAN DENSITY (UNITS/LITER) | 383332 | |
| STANDARD ERROR OF MEAN DENSITY | 58449 | |
| COEFF. OF VARIATION OF REPLICATES (%) | 21.56 | |
| TOTAL TAXA/STATION | 55 | |
| MEAN UNITS COUNTED/REPLICATE | 300.00 | |
| NUMBER OF REPLICATES | 2 | |

**** = LESS THAN .1%

TABLE 3: PHYTOPLANKTON DATA
THOMPSON RIVER STUDY

DATE: 2 JUNE

1977

| TAXA | UNITS/LITER | % |
|--------------------------|-------------|------|
| RHODOMONAS MINUTA | 232468 | 33.4 |
| RHIZOLENIA ERIENSIS | 111991 | 16.1 |
| ACNANTHES MINUTISSIMA | 39684 | 5.7 |
| ASTERIONELLA FORMOSA | 35138 | 5.1 |
| CYCLOTELLA KUTZINGIANA | 34104 | 4.9 |
| CYCLOTELLA STELLIGERA | 29843 | 4.3 |
| RHODOMONAS LACUSTRIS | 29754 | 4.3 |
| OCHROMONAS-LIKE | 18968 | 2.7 |
| CRYPTOMONAS OVATA | 17310 | 2.5 |
| SYNEDRA VAUCHERIAE | 16508 | 2.4 |
| SYNEDRA PUMPENS | 14191 | 2.0 |
| CHROMULINA-LIKE | 10875 | 1.6 |
| NITZSCHIA ACICULARIS | 10500 | 1.5 |
| CHLORELLA-LIKE #1 | 9413 | 1.4 |
| SYNEDRA RADIANS | 9270 | 1.3 |
| CYMBELLA MINUTA | 6953 | 1.0 |
| SCENEDEDMUS DENTICULATUS | 5865 | .8 |
| DINOBRYON SERTULARIA | 5723 | .8 |
| ACNANTHES LINEARIS | 5723 | .8 |
| FRAGILARIA CONSTRUENS | 4492 | .6 |
| NITZSCHIA PALEA | 3690 | .5 |
| MELOSIRA ITALICA | 3548 | .5 |
| STEPHANODISCUS ASTRAEA | 3405 | .5 |
| NITZSCHIA RECTA | 3262 | .5 |
| CRUCIGENIA QUADRATA | 2460 | .4 |
| DIATOMA TENUE | 2460 | .4 |
| ARTHROSPIRA JENNERI | 2318 | .3 |
| NITZSCHIA FRUSTULUM | 2175 | .3 |
| GOMPHONEMA OLIVACEOIDES | 2175 | .3 |
| FRAGILARIA CAPUCINA | 2175 | .3 |
| NITZSCHIA SILICA | 1230 | .2 |
| DINOBRYON BAVARICUM | 1230 | .2 |
| TETRASELMIS #1 | 1230 | .2 |
| CLADOPHORA | 1230 | .2 |
| OSCILLATORIA LIMNETICA | 1230 | .2 |
| NITZSCHIA GRACILIS | 1230 | .2 |
| OOCYSTIS PUSILLA | 1230 | .2 |
| CHLAMYDOMONAS-LIKE | 1230 | .2 |
| RHIZOCHRISIS #1 | 1230 | .2 |

TABLE 3: PHYTOPLANKTON DATA (CONTINUED)

| TAXA | STATION 450 | |
|--------------------------------------|-------------|----|
| | UNITS/LITER | % |
| SYNURA UVELLA | 1230 | .2 |
| NAVICULA PUPULA | 1087 | .2 |
| HANNAEA ARCUS | 1087 | .2 |
| MALLOMONAS PSEUDOCORONATA | 1087 | .2 |
| NAVICULA #8 | 1087 | .2 |
| NAVICULA CRYPTOCEPHALA V. VENET | 1087 | .2 |
| ACNANTHES LANCEOLATA | 1087 | .2 |
| TOTAL MEAN DENSITY (UNITS/LITER) | 695265 | |
| STANDARD ERROR OF MEAN DENSITY | 42786 | |
| COEFF. OF VARIATION OF REPLICATES(%) | 8.70 | |
| TOTAL TAXA/STATION | 46 | |
| MEAN UNITS COUNTED/REPLICATE | 300.00 | |
| NUMBER OF REPLICATES | 2 | |

**** = LESS THAN .1%

APPENDIX 3

RESUMES OF PROPOSALS FOR SETTLING SYSTEMS

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PROJECT MEMORANDUM V4251/3
WATER TREATMENT BY MEANS OF SETTLING

DATE 25 AUGUST 1978

APPENDIX 3 - RESUMES OF PROPOSALS FOR SETTLING SYSTEMS

In this Appendix, resumes are given of solids removal systems which were accepted in principle from the proposals received in response to Sandwell's letter of inquiry for water treatment (Appendix 2). Numbers used for these resumes correspond to those in Table 1 in the Introduction of this Project Memorandum.

1. SETTLING

1.1 Hydroseparator

Dorr-Oliver-Long Ltd. of Orillia, Ontario, proposed one 24 m (80 ft) diameter Hydroseparator, which is basically a circular clarifier with rake mechanism. This unit would remove at least 95 percent of 100 microns. Budget prices were not submitted.

1.2 Degritting Clarifier

Envirotech Canada Ltd. of Calgary, Alberta, proposed one 29 m (95 ft) diameter clarifier with a 12.2 m (40) ft diameter feedwell and a 4 m (13 ft) depth at the perimeter. This depth includes a 0.6 m (2 ft) allowance for ice buildup. The clarifier would be equipped with a rake for solids removal. Minimum particle size removal would be approximately 100 microns.

The quoted budget price was as follows:

| | |
|--------------------------|---------------|
| Concrete base and design | \$ 75,000 |
| Mechanism and tank shell | 110,000 |
| Erection and painting | <u>60,000</u> |
| Total | \$245,000 |

1.3 Aerated Degritter

Degremont-Infilco of Montreal, proposed one 10 x 15.7 m (33 x 51.5 ft) aerated solids removal system. Solids would collect in two bottom troughs located in the centre of the tank and parallel to its short side. Removal of solids would be by means of two travelling submerged pumps. Minimum particle size removal would be 200 microns. The quoted budget price was \$100,000, for the mechanical equipment consisting of air diffusion system and travelling solids removal pumps.

1.4 Detritor

Dorr-Oliver-Long Ltd. of Orillia, Ontario, proposed one 12.2 m (40 ft) diameter x 1.5 m (5 ft) deep Detritor, which is similar to a circular clarifier with rake mechanism, except that the liquid flows across the clarifier rather than from the centre.

The quoted budget price for rake mechanism only was \$22,600, FOB Orillia, Ontario.

1.5 Grit Collector

Rexnord (Canada) Ltd. of Willowdale, Ontario, Proposed one 4.6 m (15 ft) wide, 21.3 m (70 ft) long and 3.8 m (12.5 ft) deep settling tank with V-bottom. Solids collected at the bottom would be removed by a submerged pump mounted on a travelling bridge. Minimum particle size removal would be 200 microns.

The quoted budget price, FOB Willowdale, Ontario, for the travelling bridge complete with drive, pump, reel, electric controls and running rails was \$75,000, excluding sales taxes.

APPENDIX 4

RESUMES OF REJECTED PROPOSALS: CENTRIFUGAL CLEANERS, MEDIA FILTERS
AND MICRO FILTERS

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PROJECT MEMORANDUM V4251/3
WATER TREATMENT BY MEANS OF SETTLING

DATE 25 AUGUST 1978

APPENDIX 4 - RESUMES OF REJECTED PROPOSALS:
CENTRIFUGAL CLEANERS, MEDIA
FILTERS AND MICRO FILTERS

In this Appendix, resumes are given of solids removal systems which were rejected from the proposals received in response to Sandwell's letter of inquiry for water treatment (Appendix 2). Numbers used for the resumes correspond to those in Table 1 in the Introduction of this Project Memorandum.

2. CENTRIFUGAL CLEANER

2.1 FR Dorrclone

Dorr-Oliver-Long Ltd. of Orillia, Ontario, proposed six 122 cm (48 in.) diameter FR Dorrclones which would operate with a pressure drop of 69 kPa (10 psig) and would remove particles down to 100 microns. The quoted budget price was \$72,000 FOB Vancouver, and would include housings, liners, Vortex finders and apex valves.

2.2 Desanding Dorrclone

In a telex of 28 June 1978, Dorr-Oliver-Long Ltd., proposed either seven or twelve 76 cm (30 in.) diameter Desanding Dorrclones operating with a pressure drop of respectively 138 kPa (20 psig) and 52 kPa (7.5 psig). The quoted budget price was \$12,000 per unit, FOB Vancouver. This telex proposal superseded Dorr-Oliver-Long's original letter proposal of 7 November 1977 for six 122 (48 in.) diameter F.R. Dorrclones, see item 2.1 above.

2.3 Desanding Dorrclone

P.J. Hannah and Associates Ltd. of Vancouver, agents for U.S. Filter Fluid Systems Corporation, proposed five 76 cm (30 in.) diameter, Desanding Dorrclones each with a capacity of 330 l/s (5,200 USGPM). Each unit, requiring a pressure drop of 28 kPa (4 psig), would remove at least 95 percent of particles of 110 microns. The quoted budget price was \$250,000 and this would include the Dorrclones, valving, instrumentation and interconnecting piping within the system limits.

2.4 Celleco Cleaner

Bancroft Western Sales Ltd. of Vancouver, agents for Celleco, proposed two Celleco Cleanpac 130 Canister assemblies requiring a pressure drop of 97 kPa (14 psi). There would be a continuous reject flow of 140 l/s (2,200 USGPM). The quoted budget price for two canisters FOB Vancouver was \$136,000, excluding taxes.

Pilot study apparatus would be freely available for testing at the treatment plant site.

2.5 Smith and Loveless Pista Grit Trap

Ecodyne Ltd. of Edmonton, Alberta, proposed following two alternative Smith and Loveless grit traps:

Two Smith and Loveless Pista Grit Traps, Model No. 30, operating in parallel, each unit rated for 880 - 1320 l/s (14,000-21,000 USGPM). The quoted budget price for rotating mechanism only was \$50,000 total, FOB plant Oakville, Ontario, with freight and applicable taxes extra.

or

One Smith and Loveless Pista Grit Trap, Model No. 50, rated for 1320-2200 l/s (21,000-35,000 USGPM). The quoted budget price for rotating mechanism only was \$30,000 and conditions of sale would be as for Model No. 30 above.

3. MEDIA FILTER

3.1 Neptune Microfloc Filter

Neptune Microfloc of Corvallis, Oregon, U. S. A., proposed four twin bay gravity filters, with a total filter area of 470 m² (5000 sq ft). The backwash rate for this size of filter would be approximately 630 l/s (10,000 USGPM) and would normally run from five to eight minutes. A storage volume of 320 m³ (85,000 USG) would be required. Budget prices were not submitted.

3.2 Peacock Immedium Upflow Filter

Peacock Brothers Ltd. of Vancouver proposed their Peacock Immedium Upflow Filter which would require an area of 370-470 sq m (4,000-5,000 sq ft). Other details were not given.

3.3 Graver Filter

Ecodyne Ltd. of Edmonton, Alberta, proposed six 18.9 m (62 ft) x 6.7 m (22 ft) concrete Graver filters, operating in parallel, with air scour. The quoted budget price was \$250,000, FOB shipping points, for the supply of dual media 46 cm (18 in) anthrafilt and 30 cm (12 in) sand, together with Graver Partilock underdrain strainers, air distribution in plenum chamber, backwash troughs, gate valves and air blowers. Freight and sales taxes would be extra as would all concrete work.

3.4 Graver Monovalve Filter

Ecodyne proposed as an alternative to 3.3 seventeen 7.6 m (25 ft) diameter by 4.6 m (15 ft) high, single compartment, all steel construction, Graver Monovalve Filters, complete with frontal piping, controls, dual media 30 cm (12 in) anthrafilt and 30 cm (12 in) sand. Units would be shipped knocked down, for field assembly by others.

The quoted budget price was \$1.02 million, FOB plant Oakville, Ontario, with freight included to B.C., but all taxes extra.

4. MICRO FILTER

4.1 Cuno Automatic Flo-klean Filter

Peacock Brothers Ltd. of Vancouver proposed two AMF Cuno Automatic Flo Klean Filters - Model No. FKR16-4, each capable of filtering 790 l/s (12,500 USGPM) on heavy duty service with element spacing of 250 microns. Each filter unit would be supplied with a 5 HP backwash nozzle drive motor and a 40 HP backwash water supply pump set.

The quoted budget price was \$300,000 total, FOB Hat Creek Site.

3.2 North Water Filter

H.D. Fowler Co. Ltd. of Vancouver proposed eight North water filters, each 1.5 m (5 ft) diameter by 3.7 m (12 ft) long. 'North' water filters are manufactured by Green Bay Foundry and Machine Works. Five of these rotating units would be equipped with 75 micron retentive cloth and be able to cope with normal operating sediment conditions and the three remaining rotating filters would only be required during periods of relatively high solids loading and would be equipped with 246 micron retentive cloth. For approximately \$500, 'North' would carry out laboratory tests to determine the exact number and size of the filters required. Budget prices were not submitted.

APPENDIX 5

DORR-OLIVER-LONG HYDROSEPARATORS:

INSTALLATION LIST AND DATA

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 25 AUGUST 1978

PROJECT MEMORANDUM V4251/3
WATER TREATMENT BY MEANS OF SETTLING

APPENDIX 5 - DORR-OLIVER-LONG HYDROSEPARATORS: INSTALLATION LIST AND DATA

Dorr-Oliver-Long Hydroseparator installations are listed in Table 1. On the basis of this list, a telephone survey was conducted in order to locate installations most resembling operating conditions anticipated for the Hat Creek Project (see Table 2).

As shown in Table 2, the Eveleth Taconite Mining Company at Forbes, Minnesota, operates five Hydroseparators (Installations 14.2 and 14.4) which remove solids comparable to the proposed Hat Creek Project. These installations could be used as a reference during Final Design.

The telephone survey was limited to the companies listed in Table 2 and terminated when a representative installation had been located.

Table 1 - Installation List of Dorr-Oliver-Long Hydroseparators

| Installation No. | Company | Country | Year | Hydroseparator | | | Inflow 1/s | Additional Data in Table 2 | Comments |
|------------------|--|---------|------|----------------|-----------------|------------------------|---------------|--|----------|
| | | | | Amount | Diameter (m) | Centre Depth (m) | | | |
| 1 | Iron Ore Co. of Canada | Canada | 62 | 1 | 9.8 | - | - | Located in Labrador. | |
| 2 | Jones & Laughlin | Canada | 63 | 1 | 9.8 | 3.1 | - | x | |
| 3.1 | Potash Co. of America | Canada | 64 | 1 | 15.2 | - | 140 | x | |
| 3.2 | | | 64 | 1 | 3.7 | - | 140 | x | |
| 4 | International Minerals and Chemical | Canada | 65 | 2 | 13.7 | 3.6 | 45 | x | |
| 5 | Great Canadian Oil-Sands Ltd. | Canada | 66 | 2 | 9.1 | 2.4 | - | Used for separation of foaming grease, not comparable to Hat Creek Project. | |
| 6.1 | U.S. Steel | U.S.A. | 65 | 1 | 4.9 | 2.2 | 160 | x | |
| 6.2 | | | 70 | 6 | 11.0 | 3.1 | - | x | |
| 6.3 | | | 76 | 1 | 9.8 | - | - | x | |
| 7.1 | Hanna | U.S.A. | 65 | 5 | 9.1 | 3.4 | - | x | |
| 7.2 | | | 65 | 6 | 9.1 | 3.4 | - | x | |
| 8.1 | J. M. Huber | U.S.A. | 65 | 1 | 3.7 | 1.5 | - | | |
| 8.2 | | | 65 | 1 | 7.3 | 2.1 | - | | |
| 8.3 | | | 73 | 1 | 3.7 | 1.5 | - | | |
| 8.4 | | | 73 | 1 | 7.3 | 2.1 | - | | |
| 9 | Erie Mining | U.S.A. | 65 | 2 | 5.5 | 3.1 | - | x | |
| 10 | Swift and Co. | U.S.A. | 66 | 1 | 15.2 | 3.1 | - | | |
| 11.1 | Jackson Co. | U.S.A. | 67 | 2 | 7.9 | 3.3 | 130 | | |
| 11.2 | | | 67 | 1 | 4.9 | 1.5 | 270 | | |
| 12 | Fria | U.S.A. | 69 | 1 | 9.8 | 2.4 | 140 | | |
| 13 | Unisil Corporation | U.S.A. | 72 | 1 | 4.9 | 2.4 | - | | |
| 14.1 | Eveleth Taconite Mining Company | U.S.A. | 74 | 3 | 12.8 | 4.7 | 310 | x | |
| 14.2 | | | 74 | 3 | 13.7 | 3.0 | 1130 | x | |
| 15 | Mississippi Chemical | U.S.A. | 76 | 1 | 19.8 | 1.8 | - | | |

Note: Dash (-) means information not given.

Table 2 - Additional Data on Some Dorr-Oliver-Long Hydroseparators from Table 1

| Installation No. | Company | Place | Contact | Telephone No | Hydroseparator | | | Flow Through Each Tank | | Material Settled Out | Particle Specific Gravity | Minimum Particle Size Settled Out (Microns) | Comments |
|------------------|--|---|--------------------------|------------------------------|----------------|---------------|-------------------|------------------------|----------------------------|----------------------|---------------------------|---|---|
| | | | | | No. of Units | Tank Dia. (m) | Feedwell Dia. (m) | Inflow 1/s | Intermittent Underflow 1/s | | | | |
| 2 | Jones & Laughlin | Adams Mine, Kirkland Lake, Ontario, Canada | N. Coats | 705-567-3321 | 1 | 9.8 | - | - | - | Coarse sand | - | - | Tank mechanism no longer used. |
| 3 | Potash Company of America | Saskatoon, Saskatchewan Canada | R. Smith | 306-374-4806 | | | | | | | | | |
| 3.1 | | | | | 1 | 15.2 | 5 | 140 | 25 | Clay | - | 50 | Material settled out not comparable to Hat Creek project. Also relatively low flow rate compared with Hat Creek flow of 1660 l/s. |
| 3.2 | | | | | 1 | 3.7 | - | 140 | 25 | - | - | - | Tank mechanism no longer used. |
| 4 | International Minerals and Chemical, K2 Mine | Esterhazy, Saskatchewan, Canada | R. Bomboir | 306-745-3911 | 2 | 13.7 | - | 45 | - | Carnallite | 1.62 | - | Liquid temperature (82°C) not comparable to Hat Creek project. |
| 6 | U.S. Steel Minnesota Ore Operations | Mt. Iron, Minnesota, USA 55768 | C.W. Niemi Robertson | 218-741-9020 | - | - | - | - | - | - | - | - | Written request required before data given. |
| 7 | Hanna | Cooley, Minnesota, USA | P. Koskinen R. Jensen | 218-885-1020 218-262-3451 | - | - | - | - | - | Silica | - | - | Written request required before additional data given. |
| 9 | Erie Mining Company | Box 847 Hoyt Lakes, Minnesota, USA 55750 | C. Keith | 218-225-2171 | - | - | - | - | - | - | - | - | Written request required before data given. |
| 14 | Eveleth Taconite Mining Company | Forbes, Minnesota, USA | D. Wilson D. Coyle | 218-749-1460 | | | | | | | | | |
| 14.1 | | | | | 3 | 12.8 | 4 | 310 | 60 | Magnetite | 4.9-5.2 | 40 | Material settled out not comparable to Hat Creek Project. |
| 14.2 | | | | | 3 | 13.7 | 6 | 1130 | 20 | Silica | 2.6-2.7 | 150 | Application similar to Hat Creek Project. |
| 14.3 | | | | | 4 | 8 | 2 | 240 | 50 | Magnetite | 4.9-5.2 | 40 | Material settled out not comparable to Hat Creek project. |
| 14.4 | | | | | 2 | 12 | 5 | 1080 | 25 | Silica | 2.6-2.7 | 150 | Application similar to Hat Creek Project. |


Notes: 1. Dash (-) means information not given

2. All above installations are inside process buildings and operate with a liquid temperature equal to that of the ambient air, except for No. 4 (see comment).

3. Installation Nos. 14.1 and 14.2 are extensions to the original installations, Nos. 14.3 and 14.4. The original installations were not by D.O.L.

APPENDIX 6

ILLUSTRATIONS



| | | | | |
|----------|-------------|-----|-----|-----|
| APPROVED | | DAY | NO. | YR. |
| DATE | DR'N. SH | | | |
| | CHK'D. | | | |
| A | APP'D. | | | |
| | APP'D. A.C. | 75 | 8 | 78 |

HAT CREEK PROJECT
COOLING WATER SUPPLY
WATER TREATMENT BY MEANS OF SETTLING
SETTLING RATE / PARTICLE DIAMETER CURVES

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER **B. C.**




SANDWELL

DWG. A 4251/3-1

REV

THIS DRAWING IS THE PROPERTY OF SANDWELL AND MUST BE RETURNED TO SANDWELL ON REQUEST. ITS CONTENTS ARE SECRET AND CONFIDENTIAL. ANY INFORMATION OBTAINED BY INSPECTION OF THIS DRAWING SHALL NOT BE USED FOR ANY OTHER THAN THE SPECIFIC PURPOSE FOR WHICH ITS INSPECTION IS AUTHORIZED BY SANDWELL.



| | | | | |
|----------|-------------|-----|-----|-----|
| APPROVED | | DAY | NO. | YR. |
| DATE | DR.'N. SH | | | |
| A | CHK'D. | | | |
| | APP'D. A.C. | 25 | 8 | 78 |

HAT CREEK PROJECT
 COOLING WATER SUPPLY
 WATER TREATMENT BY MEANS OF SETTLING
 KINEMATIC VISCOSITY / TEMPERATURE CURVE



THIS DRAWING IS THE PROPERTY OF SANDWELL AND MUST BE RETURNED TO SANDWELL ON REQUEST. ITS CONTENTS ARE SECRET AND CONFIDENTIAL. ANY INFORMATION OBTAINED BY INSPECTION OF THIS DRAWING SHALL NOT BE USED FOR ANY OTHER THAN THE SPECIFIC PURPOSE FOR WHICH ITS INSPECTION IS AUTHORIZED BY SANDWELL.



SANDWELL

B.C. HYDRO AND POWER AUTHORITY
 VANCOUVER
 B. C.

DWG. A 4251/3-2 REV

SANDWELL SCA INC.

CLARIFIER DIAMETER 'D' (m); (FEEDWELL DIAMETER USED IS 12m)



CLARIFIER

NOTES:

1. DIAMETER INCLUDES A FACTOR OF SAFETY OF 2.
2. CLARIFIER DIAMETER BASED ON AN INFLOW OF 1,660 l/s (26,250 USGPM).
3. CURVES DRAWN FOR PARTICLE SPECIFIC GRAVITY OF 2.65

CLARIFIER DIAMETER 'D' (ft); (FEEDWELL DIAMETER USED IS 40 ft)

| | | | | | |
|----------|----------|------|-----|-----|-----|
| APPROVED | | | DAY | NO. | YR. |
| DATE | DR.'N. | SH | | | |
| | CH.'K'D. | | | | |
| A | APP'D. | | | | |
| | APP'D. | A.C. | 25 | 8 | 78 |

HAT CREEK PROJECT
 COOLING WATER SUPPLY
 WATER TREATMENT BY MEANS OF SETTLING
 CLARIFIER DIAM./PARTICLE SIZE & TEMPERATURE



SANDWELL


B. C. HYDRO AND POWER AUTHORITY
 VANCOUVER

DWG. A 4251/3-3

REV


SANDWELL 550 A30

WATER TEMPERATURE (°C)



NOTE:
DATA RECORDED AT
SPENCES BRIDGE

TIME (MONTHS)

| | | | | | |
|--|--------|------|-----|-----|--|
| APPROVED | | DAY | NO. | YR. | HAT CREEK PROJECT COOLING WATER SUPPLY WATER TREATMENT BY MEANS OF SETTLING THOMPSON RIVER HYDROGRAPH & TEMP/TIME CURVE |
| DATE | DR.'N. | SH | | | |
| A | CHK'D. | | | | |
| | APP'D. | R.C. | 28 | 78 | |
| <small>THIS DRAWING IS THE PROPERTY OF SANDWELL AND MUST BE RETURNED TO SANDWELL ON REQUEST ITS CONTENTS ARE SECRET AND CONFIDENTIAL ANY INFORMATION OBTAINED BY INSPECTION OF THIS DRAWING SHALL NOT BE USED FOR ANY OTHER THAN THE SPECIFIC PURPOSE FOR WHICH ITS INSPECTION IS AUTHORIZED BY SANDWELL</small> | | | | | B. C. HYDRO AND POWER AUTHORITY VANCOUVER |
|  SANDWELL | | | | | B. C. DWG. A 4251/3-4 |
| | | | | | REV |

PROJECT MEMORANDUM V4251/4

RESERVOIR RELOCATION

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 8 SEPTEMBER 1978

PROJECT MEMORANDUM V4251/4
RESERVOIR RELOCATION

CONTENTS

| | |
|----------------------------------|---|
| INTRODUCTION | 1 |
| PIPELINE ROUTE | 1 |
| FLOW CONTROL | 1 |
| PARTIALLY-FULL FLOW SECTION | 3 |
| LOCATION OF NO 2 BOOSTER STATION | 4 |
| PIPELINE INSPECTION | 4 |
| PIPELINE FRICTION | 4 |
| WATERHAMMER STUDIES | 4 |
| CAPITAL COST | 5 |
| ENERGY COST | 7 |
| COMPARISON OF CASE 1 AND CASE 2 | 8 |
| CONCLUSIONS | 8 |

APPENDICES

- 1 - Scope of Work
- 2 - Details of Cost Estimate
- 3 - Illustrations

B4251/4-1 Pipeline Route

D4251/4-2 Pipeline Profile

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 8 SEPTEMBER 1978

PROJECT MEMORANDUM V4251/4
RESERVOIR RELOCATION

INTRODUCTION

Mr. C.K. Harman of B.C. Hydro and Power Authority, in a letter dated 25 April 1978 to Mr. A. Copeland of Sandwell, asked what effect relocating the power plant water reservoir would have on the cooling water supply scheme and on the preliminary engineering cost estimate. The reservoir would be relocated to upper Medicine Creek, as shown on Drawing B4251/4 - 1*.

The Scope of Work was defined in correspondence dated 2 and 12 May 1978, quoted in Appendix 1. The work includes choosing a compatible combination of pipeline route, reservoir discharge arrangement, and with B.C. Hydro assistance, waterhammer control scheme. The cost estimate was prepared by determining the cost of items which are different from the Preliminary Design estimate, and then adjusting the estimate accordingly.

PIPELINE ROUTE

The route selected as being most compatible with overall economy and with the relocated reservoir location is shown on Drawing B4251/4 - 1, and in profile on Drawing D4251/4 - 2. The route is that of Alternative 3 from Project Memorandum V4251/1, Pipeline Route Review, except that it is shorter by 1 km because it has been revised between Station 18 + 500 and the relocated power plant reservoir. This route was selected for the reservoir relocation because it offers the advantage of a high point near Station 10 + 100 suitable for a simple surge tank, from which flow would be by gravity to the plant reservoir. This arrangement simplifies waterhammer control, and also provides the cost and other benefits of Alternative 3 which were identified in Project Memorandum V4251/1.

FLOW CONTROL

Drawing D4251/4 - 2, Pipeline Profile, shows that along the selected route, the pipeline has two summits about 8.5 km apart and at nearly the same elevation, and that from the second summit the pipeline descends to the plant reservoir. This profile creates special problems for flow control, and invalidates the one-way surge tank** configuration proposed for the Preliminary Design route.

* For Drawings see Appendix 3, Illustrations.

** A one-way surge tank is a tank filled with water, isolated from the pipeline by check valves, so that when the piezometric head at the tank drops below the water level in the tank the check valves open and water from the tank flows into the pipeline to reduce waterhammer.

In the early stages of this study, it was desirable to develop a scheme using a one-way surge tank on the first summit to enable comparison between similar schemes for the relocated reservoir and for the Preliminary Design reservoir. However, such a scheme was not developed because a one-way tank there would not protect the pipeline for the following reason: the one-way tank, being higher than the second summit, would drain when pumping stopped. When pumping resumed, the tank would refill slowly through a control valve, and it is possible that maximum pipeline discharge could be reached with very little water in the tank. Should power fail at this time, the tank would not protect the pipeline.

This problem did not exist with the Preliminary Design arrangement because the one-way tanks were located below the pipeline summit; thus they would refill during the time pumping was stopped.

There are perhaps ways to avoid this problem with the one-way tank, such as lowering the pipeline profile and tank elevation, interlocking pump start-up with tank level, or even changing the pipeline route. However, the best way to avoid the problem is to use a simple surge tank* instead of a one-way surge tank. The simple tank requires no valves and is therefore more reliable. This tank would be located on the first summit, with maximum water level at about elevation 1340. The discharge throughout the pipeline cannot reach maximum until the simple tank is full, because the head in the tank is needed to drive the water downstream. Therefore, the pipeline is protected for the maximum flow condition.

The flow from the simple tank to the plant reservoir would be by gravity since the tank becomes the high point in the profile. Two cases for controlling this flow have been developed, as shown on Drawing D4251/4 - 2, and as described below:

Case 1: Control Valve at Maximum Reservoir Level

The valve, with an energy-dissipating fitting to prevent cavitation** damage, keeps the pipe full and maintains the water level in the simple tank on the first summit. To reduce the height of tank required, a 900mm diameter pipeline is necessary between the tank and the valve.

Case 2: Weir at Second Summit

The weir, at elevation 1302 in a tank at the second summit, keeps the water level at that elevation when pumping stops. At the first summit, the pipeline is buried below elevation 1302, but the simple tank drains when pumping stops. The tank would refill when flow resumes. Again, a 900mm diameter pipeline is needed between the summits.

* A simple surge tank is a tank filled with water, connected directly to the pipeline. This tank controls waterhammer by accepting or supplying water when flow conditions change.

** Cavitation is caused by the collapse of cavities of vapour which tend to form in the flow when absolute pressure drops to the fluid vapour pressure. The collapse causes serious problems of noise, vibration, and pitting of surfaces.

PARTIALLY-FULL FLOW SECTION

The pipeline section from the control valve to the plant reservoir in Case 1, and from the weir on the second summit to the plant reservoir in Case 2, is designed to carry the maximum discharge in a buried partially-full pipe. The partially-full system simplifies flow control. Full flow, on the other hand, would require a submerged control valve on the downstream end of the pipeline. This concept was rejected, as the submerged control valve would be troublesome for operation and maintenance.

Breather pipes rather than air release valves would allow air exchange. The pipeline would end at a small concrete stilling basin below low water level. Transition from partially-full to full flow would occur inside the pipe at the reservoir level.

A canal or open channel along the surface would be possible with either case, but was rejected as it would be susceptible to freezing. In the selected arrangement, the pipe would be buried below the depth of frost penetration in the ground; thus the water in the pipe would not freeze if the pipe were full. However, as there would be an air-water interface, and as the air could escape through the breather pipes, there could be heat lost from the water and ultimately from the surrounding soil. Remedies which may include heat tracing, heating the air in the pipe, or deeper burial of the pipe, should be examined during Final Design if the heat loss were too great.

As the water in the partially-full flow section of the pipeline drops as much as 87 m with Case 2, the design must ensure that the water velocity does not become so high as to cause severe damage to the pipeline. The maximum velocity in the pipeline would be 7.9 m/s under uniform flow conditions. (The calculations for non-uniform flow are not warranted at this time as the actual profile of the field-bent pipe will not be known until Final Design.)

B.C. Hydro advised that coal tar epoxy or other thin film linings, as were proposed in the Preliminary Design for the pipeline interior, have an excellent operating record with water velocities up to 18 - 21 m/s. As the calculated maximum velocity of 7.9 m/s is well below that level, the design is acceptable for this portion of the pipeline.

LOCATION OF N^o 2 BOOSTER STATION

The total dynamic head for Cases 1 and 2 being about 150 m less than for Alternative 3 of Project Memorandum V4251/1, it was necessary to relocate the N^o 2 Booster Station to elevation 775 m from elevation 835 m. On topographic maps and air photos, ground conditions appear about the same. This location is closer to the overflow reservoir, thus the overflow trench required is shorter. Geotechnical evaluation and field appraisal, as were recommended in Project Memorandum V4251/1, are still necessary to confirm this location.

PIPELINE INSPECTION

The concept of inspecting the pipeline using "smart pigs" is discussed in Report V4191/1. In order to use pigs with the Case 1 and Case 2 arrangements, two extra pig traps are needed each side of the simple surge tank. These traps are necessary because the pipe diameter changes at the tank from 800mm to 900mm, too great a change to use the same pig without modifying the driving cups.

The partially-full portion of pipeline to the reservoir from the control valve in Case 1, and from the weir tank in Case 2, could not be inspected the same way because of the breather pipes which would release pressure needed to drive the pigs. However, this portion could be visually inspected as it would drain freely. Moreover, the consequences of leakage are insignificant here compared to pressurized portions of the pipeline.

PIPELINE FRICTION

In any pumping system, the delivery of the design discharge depends on the pipeline friction being as expected at the time of design. In Preliminary Design, pipeline friction was calculated for coal tar epoxy lining and for the 35 year project lifetime, and the pumps were rated accordingly. However, in the unlikely event that the pipeline interior became badly corroded, so that the pumps could no longer supply the design discharge, a booster pump could be added to each booster station to regain the full discharge capability.

For Cases 1 and 2, a substantial increase in friction would cause the simple surge tank to overflow, and a possible remedy would be to make the tank higher. During Final Design, it may be decided to avoid this problem by increasing the pipe diameter between the simple surge tank and the control valve (Case 1) or weir tank (Case 2).

WATERHAMMER STUDIES

The results of B.C. Hydro's waterhammer studies of the two cases are contained in a letter dated 30 June 1978 from Mr. I.C. Dirom of B.C. Hydro to Mr. A.P. Basham of Sandwell. The following measures are sufficient to control the design pressure rise to less than 10% of the rated head, and to prevent water-column separation:

Case 1a. Nº 1 to Nº 2 Booster Station

- Nº 1 Booster Pump - Motor inertia = 175kg.m^2 each
- One-way surge tank required at summit of Elephant Hill, 4m in diameter
- Pump discharge valve closing time = 70 s

b. Nº 2 Booster Station to Control Valve

- Nº 2 Booster Pump - Motor inertia = 175kg.m^2 each
- Pump discharge valve closing time = 55 s
- Simple surge tank at Station 10 + 100 to be 5m in diameter. Design upsurge to be 5m above maximum steady water level

Case 2a. Nº 1 to Nº 2 Booster Station

- All as Case 1

b. Nº 2 Booster Station to Plant Reservoir

- Nº 2 Booster Pump inertia as Case 1
- Pump discharge valve closing time = 55 s
- Simple surge tank as Case 1
- Tank with weir at Station 18 + 500 to be 8m in diameter.

The variations from the waterhammer control measures appropriate to the Preliminary Design are notably the simple rather than one-way surge tank on the summit of Cornwall Hill and the necessity of a one-way surge tank on Elephant Hill. These result from the lower total head and altered profile. It is also notable that the booster pump inertia requirement, less than half of that for Preliminary Design, attests to the superior waterhammer behaviour of this configuration.

The B.C. Hydro waterhammer study group prefers Case 2 because the control valve in the Case 1 arrangement could cavitate at low discharges. It could, therefore, require expensive maintenance if the energy dissipator did not function properly.

CAPITAL COST

In accordance with Item 8 of Appendix 2, the following cost estimate has been prepared. This estimate is not a complete re-examination of the Preliminary Design estimate, rather it reflects adjustments to the various categories because of the selection of Alternative 3 (Project Memorandum V4251/1) and because of the relocated water reservoir. For ease of comparison, the Preliminary Design estimate and the estimate for Alternative 3 are also given.

A detailed breakdown of the items in the estimate which have been changed is provided in Appendix 2 for Case 1 and Case 2, and in Project Memorandum V4251/1 for Alternative 3.

SANDWELL

Table 1 - Cost Estimate

| <u>Account</u> | <u>Item</u> | <u>Preliminary Design (Report V4191/1)</u> | <u>Adjusted For Alternative 3 (PM V4251/1)</u> | <u>Adjusted For Case 1</u> | <u>Adjusted For Case 2</u> |
|-------------------|-------------------------------|--|--|----------------------------|----------------------------|
| <u>STRUCTURES</u> | | | | | |
| 271.00 | Thompson River Intake | \$ 2,640,000 | \$ 2,640,000 | \$ 2,640,000 | \$ 2,640,000 |
| 272.00 | Water Pipeline | 15,535,000 | 14,940,000 | 14,885,000 | 14,925,000 |
| 273.00 | No. 1 Booster Station | 950,000 | 950,000 | 950,000 | 950,000 |
| 274.00 | No. 2 Booster Station | <u>1,755,000</u> | <u>1,770,000</u> | <u>1,620,000</u> | <u>1,620,000</u> |
| | Total Structures | \$20,880,000 | \$20,300,000 | \$20,095,000 | \$20,135,000 |
| <u>EQUIPMENT</u> | | | | | |
| 271.00 | Thompson River Intake | \$ 1,780,000 | \$ 1,780,000 | \$ 1,780,000 | \$ 1,780,000 |
| 272.00 | Water Pipeline | 2,385,000 | 2,635,000 | 2,185,000 | 2,370,000 |
| 273.00 | No. 1 Booster Station | 3,430,000 | 3,430,000 | 3,370,000 | 3,370,000 |
| 274.00 | No. 2 Booster Station | 3,445,000 | 3,445,000 | 3,385,000 | 3,385,000 |
| 291.00 | Power Supply and Distribution | <u>2,345,000</u> | <u>2,395,000</u> | <u>2,295,000</u> | <u>2,195,000</u> |
| | Total Equipment | \$13,385,000 | \$13,685,000 | \$13,015,000 | \$13,100,000 |
| | Total Direct Cost | \$34,265,000 | \$33,985,000 | \$33,110,000 | \$33,235,000 |
| | Owner's Construction Overhead | \$ 2,740,000 | \$ 2,715,000 | \$ 2,660,000 | \$ 2,660,000 |
| | Engineering | 3,500,000 | 3,500,000 | 3,500,000 | 3,500,000 |
| | Contingencies | <u>5,245,000</u> | <u>5,100,000</u> | <u>4,980,000</u> | <u>5,005,000</u> |
| | Total Construction Cost | \$45,750,000 | \$45,300,000 | \$44,250,000 | \$44,400,000 |
| | Corporate Overhead | <u>2,250,000</u> | <u>2,250,000</u> | <u>2,200,000</u> | <u>2,200,000</u> |
| | Total Capital Cost | \$48,000,000 | \$47,550,000 | \$46,450,000 | \$46,600,000 |

ENERGY COST

Energy cost for pumping from the clearwell at elevation 325 m to the plant reservoir over the 35 year project lifetime is shown on Table 2.

Table 2 - Present Value of Energy Cost
Based on 20 Mills per kWh and 8% Interest
 (Total volume: 22.9 million m³/a)

| | Preliminary Design (Report V4191/1) | Alternative 3 (P.M. V4251/1) | Case 1 | Case 2 |
|---|---|---------------------------------|--------------|--------------|
| Minimum (Pumping at 725 l/s continuously) | \$20,906,000 | \$20,861,000 | \$19,774,000 | \$19,213,000 |
| Maximum (Pumping at 1580 l/s for 46% of the time) | \$24,343,000 | \$24,133,000 | \$21,252,000 | \$21,301,000 |

As mentioned in Project Memorandum V4251/1, Alternative 3 benefits from a shorter pipeline route than the Preliminary Design. Cases 1 and 2 benefit from a pipeline route which is shorter yet, from the use of 900 m diameter pipe, and from a lower elevation of the plant reservoir. Case 2 saves about \$0.5 million over Case 1 for the continuous pumping condition because the weir control allows a lower water level in the simple surge tank. In Case 1, this water level would be constant regardless of discharge.

As the relocated reservoir would be located on Medicine Creek, it could be designed to collect run-off from this stream and thus reduce the amount needed from the Thompson River by 4 million cubic metres per year (from 22.9 to 18.9 million cubic metres per year).

Additional cost data for the relocated reservoir utilizing Medicine Creek water are given on Table 3 in two groups: the first group where the full 4 million cubic metres is taken, and the second group where 2.5 million cubic metres is taken and the balance is diverted for irrigation.

Table 3 - Present Value of Energy Cost Where
Medicine Creek Water Collected (basis as Table 2)

| | Volume used from Medicine Creek (million m ³ /a) | Case 1 | Case 2 |
|---|--|--------------|--------------|
| Minimum (Pumping at 598 l/s continuously) | 4.0 | \$16,206,000 | \$15,699,000 |
| Maximum (Pumping at 1580 l/s for 38% of the time) | 4.0 | \$17,528,000 | \$17,575,000 |
| Minimum (Pumping at 646 l/s continuously) | 2.5 | \$17,548,000 | \$17,017,000 |
| Maximum (Pumping at 1580 l/s for 41% of the time) | 2.5 | \$18,936,000 | \$18,972,000 |

Cases 1 and 2 thus can save up to \$3.7 million by collecting 4 million m³/a of Medicine Creek run-off. (\$21,301,000 - \$17,575,000 = \$3,726,000)

COMPARISON OF CASE 1 AND CASE 2

The advantages of Case 1 over Case 2 are:

- The capital cost is \$150,000 less
- A greater length of pipeline can be pigged

The advantages of Case 2 over Case 1 are:

- The energy cost for continuous discharge is \$560,000 less
- The simple surge tank drains when pumping stops, therefore Case 1 requires less energy to prevent freezing in the tank
- The control valve and energy dissipator at the plant reservoir, which would be potentially troublesome maintenance items, are avoided

As the advantages of Case 2 over Case 1 outweigh those of Case 1 over Case 2, Sandwell recommends Case 2 for further consideration should B.C. Hydro decide to relocate the plant reservoir to Upper Medicine Creek.

CONCLUSIONS

The implications of relocating the power plant reservoir to Upper Medicine Creek, using Case 2, would be as shown on Table 4. Since the Preliminary Design route is no longer appropriate to either reservoir location, it is excluded from the comparison.

Table 4 - Implications of Reservoir Relocation

| <u>Item</u> | <u>Plant Reservoir Preliminary Design</u> | <u>Plant Reservoir Relocated - Case 2</u> |
|----------------------|---|---|
| Route | Alternative 3 (P.M. V4251/1) | Altered beyond Sta 18 + 500 Shorter by 1 km |
| Pipe Size | Uniform 800mm diameter | 7.3 km of 900mm diameter |
| Flow Controls | Self-regulating at booster stations | Self-regulating at booster stations |
| Waterhammer Controls | 3 one-way surge tanks | 1 one-way surge tank (Elephant Hill) 1 simple surge tank 1 weir tank |
| | 400 kg.m ² flywheel inertia | 175 kg.m ² flywheel inertia |
| Capital Cost | \$47.6 million | \$46.6 million |
| Energy Cost | \$20.9-\$24.1 million | \$15.7*-\$21.3 million |

These implications can be incorporated into B.C. Hydro's considerations of other costs and benefits which would accrue from relocating the power plant reservoir.

*Using 4 million m³/a of Medicine Creek water

Prepared by



A. P. Basham, M. Eng., P. Eng.

Approved by



A. Copeland, P. Eng.
Project Engineer

APPENDIX 1

SCOPE OF WORK

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

DATE 8 SEPTEMBER 1978

PROJECT MEMORANDUM V4251/4
RESERVOIR RELOCATION

APPENDIX 1 - SCOPE OF WORK

In letters to Mr. C.K. Harman of B.C. Hydro and Power Authority dated 2 May 1978 and 12 May 1978 from Mr. D.A. Brundrett of Sandwell, the following Scope of Work was defined for determining the effects on the cooling water supply scheme of relocating the power plant water reservoir to Upper Medicine Creek:

1. (2 May) Since a power line corridor will not be required, the pipeline route downstream of Boston Flats will be reviewed. Data in Project Memorandum V4251/1 will be used for the pipeline routing between Boston Flats and McLean Lake. Alternative 3, recommended in this Project Memorandum, may have to be reconsidered as this route may not be compatible with a lower plant reservoir.

B.C. Hydro is to advise whether or not the proposed power plant access road is to be considered when selecting a new pipeline route.
2. (12 May) The selection of a suitable location for the second booster pumping station: this work will be carried out with the same level of effort as was done for Project Memorandum V4251/1, Pipeline Route Review.
3. (2 May) Pipe wall thickness requirements will be reviewed, because of a lower total discharge head.
4. (2 May) Since the divide between Cornwall Creek and Medicine Creek is approximately at elevation 1290 m, or 65 m above the minimum reservoir level, we will review the discharge into the reservoir. The result may be different from the solution recommended in Report V4191/1 where the entire pipeline profile was below minimum reservoir level.
5. (2 May) Although the total pump discharge head will be slightly lower and the total annual water demands will be slightly less because of Medicine Creek flows, we will assume that the following water supply parameters and components will remain unchanged:
 - 5.1 Design capacity of 1580 l/s
 - 5.2 Entire system from intake to the point where the high pressure pipeline commences at the No 1 Booster Station
 - 5.3 Pipeline diameter of 800mm
 - 5.4 Basic selection and cost of booster pumps and motors
 - 5.5 System configuration of two booster pumping stations
 - 5.6 Arrangement and size of booster pumping stations

6. (2 May) Dr. M.H. Chaudhry of B.C. Hydro will be responsible for waterhammer protection. Sandwell's work will be carried out in close consultation with Dr. Chaudhry so that specific portions of this review, such as the location of the second booster station and the cost estimate, will not commence until the proposed route has been found acceptable from a waterhammer protection point of view.
7. (12 May) The following drawings will be prepared:
- 7.1 Overall pipeline route similar to Drawing B4251/1 - 1, Project Memorandum V4251/1
 - 7.2 A new profile similar to Drawing D4191 - 15, Report V4191/1
8. (12 May) We will prepare a cost estimate with the same level of effort as that for our Project Memorandum V4251/1. This would be reported in the form of a "Summary of Cost Estimate" similar to Table 8, page 58, Volume 1, Report V4191/1, except that no breakdown of material and labour will be provided. Only total costs will be given for each item.
9. (2 May) The results will be presented in the form of a Project Memorandum.

The following items should be noted, referring to the numbers above:

- 1. B.C. Hydro has advised that, from about Station 18 + 500, the new pipeline route need not include consideration of the proposed power plant access road.
- 5.3 Pipeline diameters were modified in some areas for hydraulic reasons.

APPENDIX 2

DETAILS OF COST ESTIMATE

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B.C. HYDRO AND POWER AUTHORITY
VANCOUVER B.C.

PROJECT MEMORANDUM V4251/4
RESERVOIR RELOCATION

DATE 8 SEPTEMBER 1978

APPENDIX 2 - DETAILS OF COST ESTIMATE (Showing all altered items.)

| <u>Account</u> | <u>Item</u> | <u>Preliminary Design</u> | <u>Alternative 3</u> | <u>Case 1</u> | <u>Case 2</u> | <u>Notes</u> |
|----------------|-------------------------|---------------------------|----------------------|---------------|---------------|--------------|
| | <u>STRUCTURES</u> | | | | | |
| 272.00 | <u>Pipeline</u> | | | | | |
| 272.63 | Grading | \$ 295,000 | \$ 268,900 | \$ 263,600 | \$ 263,600 | 1 |
| 272.65 | Pipe | 4,880,000 | 4,616,800 | 4,418,000 | 4,369,800 | 1,2,3 |
| 272.66 | Haul and String | 340,000 | 340,000 | 325,100 | 325,100 | 1 |
| 272.67 | Trenching | 3,400,000 | 3,388,500 | 3,378,900 | 3,471,600 | 1,3,4,6 |
| 272.69 | Bending | 510,000 | 510,000 | 520,000 | 520,000 | 5 |
| 272.70 | Line-up | 525,000 | 495,200 | 474,200 | 474,200 | 1 |
| 272.71 | Welding | 450,000 | 424,200 | 426,400 | 421,400 | 1,2,3 |
| 272.74 | Lower-in and tie-in | 640,000 | 607,000 | 607,000 | 607,000 | 1 |
| 272.75 | Bedding | 365,000 | 334,800 | 329,300 | 329,300 | 1,3 |
| 272.77 | Testing - Hydro and pig | 120,000 | 120,000 | 140,000 | 140,000 | 5 |
| 272.78 | Backfill | 235,000 | 214,400 | 197,200 | 197,200 | 6 |
| 272.86 | Drainage pipelines | 1,305,000 | 1,149,200 | 873,600 | 873,600 | 7 |
| 272.88 | Pig traps | 925,000 | 925,000 | 1,387,000 | 1,387,000 | 8 |
| | All other pipeline | 1,545,000 | 1,545,000 | 1,545,000 | 1,545,000 | |
| | Total (rounded) | \$15,535,000 | \$14,940,000 | \$14,885,000 | \$14,925,000 | |

| <u>Account</u> | <u>Item</u> | <u>Preliminary Design</u> | <u>Alternative 3</u> | <u>Case 1</u> | <u>Case 2</u> | <u>Notes</u> |
|----------------|---------------------------------|---------------------------|----------------------|---------------|---------------|--------------|
| 274.00 | <u>No. 2 Booster Station</u> | | | | | |
| 274.86 | Drainage pipelines | \$ 80,000 | \$ 246,000 | \$ 96,000 | \$ 96,000 | 9 |
| 274.93 | Overflow reservoir | 890,000 | 620,000 | 620,000 | 620,000 | 10 |
| 274.94 | Access roads | 35,000 | 155,000 | 155,000 | 155,000 | 10 |
| | All other No. 2 Booster Station | 750,000 | 750,000 | 750,000 | 750,000 | |
| | Total (rounded) | \$ 1,755,000 | \$ 1,770,000 | \$ 1,620,000 | \$ 1,620,000 | |
| | <u>EQUIPMENT</u> | | | | | |
| 272.00 | <u>Pipeline</u> | | | | | |
| 272.38 | Process controls | \$ 370,000 | \$ 370,000 | \$ 445,000 | \$ 370,000 | 11 |
| 272.43 | Starters and MCC | 40,000 | 40,000 | 31,100 | 31,100 | 12 |
| 272.44 | Power wiring | 260,000 | 260,000 | 202,200 | 202,200 | 12 |
| 272.48 | Telemetry system wiring | 440,000 | 440,000 | 411,300 | 411,300 | 1 |
| 272.83 | Surge tank systems | 750,000 | 1,000,000 | 603,300 | 860,900 | 13 |
| 272.89 | Air/vacuum valves | 365,000 | 365,000 | 332,800 | 332,800 | 14 |
| | All other pipeline | 160,000 | 160,000 | 160,000 | 160,000 | |
| | Total (rounded) | \$ 2,385,000 | \$ 2,635,000 | \$ 2,185,000 | \$ 2,370,000 | |
| 273.00 | <u>No. 1 Booster Station</u> | | | | | |
| 273.31 | Pumps | \$ 935,000 | \$ 935,000 | \$ 875,000 | \$ 875,000 | 15 |
| | All other No. 1 Booster Station | 2,495,000 | 2,495,000 | 2,495,000 | 2,495,000 | |
| | Total (rounded) | \$ 3,430,000 | \$ 3,430,000 | \$ 3,370,000 | \$ 3,370,000 | |

SANDWELL

| <u>Account</u> | <u>Item</u> | <u>Preliminary Design</u> | <u>Alternative 3</u> | <u>Case 1</u> | <u>Case 2</u> | <u>Notes</u> |
|----------------|---|---------------------------|----------------------|---------------|---------------|--------------|
| 274.00 | <u>No. 2 Booster Station</u> | | | | | |
| 274.31 | Pumps | \$ 935,000 | \$ 935,000 | \$ 875,000 | \$ 875,000 | 15 |
| | All other No. 2 Booster Station | 2,510,000 | 2,510,000 | 2,510,000 | 2,510,000 | |
| | Total (rounded) | \$ 3,445,000 | \$ 3,445,000 | \$ 3,385,000 | \$ 3,385,000 | |
| 291.00 | <u>Power Supply and Distribution</u> | | | | | |
| 291.51 | 69 kV transmission lines | \$ Excluded | \$ 50,000 | \$ 50,000 | \$ 50,000 | 10 |
| 291.54 | Pipeline sub-stations | 895,000 | 895,000 | 795,600 | 696,000 | 12,16 |
| | All other power supply and distribution | 1,450,000 | 1,450,000 | 1,450,000 | 1,450,000 | |
| | Total (rounded) | \$ 2,345,000 | \$ 2,395,000 | \$ 2,295,000 | \$ 2,195,000 | |





Notes

1. Differences in length.
2. Differences in wall thickness distribution.
3. Difference in pipe diameter.
4. Extra depth at first summit included for Case 2.
5. Includes an allowance for the extra difficulty caused by changing pipe diameter.
6. Differences in depth to rock.
7. Two drainage pipelines no longer needed.
8. Two extra pig traps.
9. Shorter length of overflow pipeline.
10. See Project Memorandum V4251/1.
11. Includes control valve for Case 1.
12. Electrical equipment at 2 drainage pipelines deleted.
13. Case 2 includes weir tank.
14. Two fewer air/vacuum valves needed.
15. Booster pump flywheel inertia reduced.
16. Includes sub-station for control valve, Case 1.

TOTAL 2,885,000

APPENDIX 3

ILLUSTRATIONS



NOTES:

- FOR PIPELINE ROUTE SEE REF 1.
- RATED HEAD OF PUMPS CASE 1, 556.5 M. CASE 2, 558.1.
- LENGTHS AND STATIONS HAVE BEEN DETERMINED APPROXIMATELY.

Scales as drawn

| | | | | | |
|-------|-----|-------|------|------|------------|
| DES | | REC'D | | DATE | |
| DWR | 9/1 | APP'D | | DATE | |
| CHK'D | AFB | APP'D | | DATE | |
| REP | | APP'D | R.C. | DATE | SEPT. 1978 |
| SURD | | DATE | | | |

SANDWELL DWG. NO. P4251/4-2
EFTIS - COLUMBIA HYDRO AND POWER AUTHORITY
HAT CREEK PROJECT
COOLING WATER SUPPLY
RESERVOIR RELOCATION
PIPELINE PROFILE
AS SHOWN DWG NO. D4251/4-2

| NO. | REVISIONS | DATE | MADE | CHK'D | APP'D | REMARKS |
|-----|--------------------------|------|------|-------|-------|---------|
| 1 | B4251/4-1 PIPELINE ROUTE | | | | | |

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER B. C.

PROJECT MEMORANDUM V4251/5
THOMPSON RIVER - WATER LEVEL DATA

DATE 31 JULY 1978

CONTENTS

| | |
|------------|---|
| PURPOSE | 1 |
| STATIONS | 1 |
| DATA | 2 |
| APPENDIX 1 | |

Table 1 and Illustrations

- Table 1 - Water Surface Elevations
- A4251/5-1 - Site 10 - Stations
- D4251/5-2 - Hydrographs - 1976 through July 1978

PROJECT V4251
HAT CREEK PROJECT
COOLING WATER SUPPLY

B. C. HYDRO AND POWER AUTHORITY
VANCOUVER B. C.

PROJECT MEMORANDUM V4251/5
THOMPSON RIVER - WATER LEVEL DATA

DATE 31 JULY 1978

PURPOSE

This Project Memorandum supplements water level data for intake Site 10 contained in Volume 2 of Sandwell's Report V4191/1 of March 1978, "Preliminary Design Study", Hat Creek Project, Appendix 8, Project Memorandum V4191/3, "Thompson River - Water Level Data". The water levels in PM V4191/3 were taken at bimonthly intervals from 6 December 1976 until 15 July 1977, during low winter flows and spring freshet.

Water level readings reported here were resumed on 14 December 1977 on a bimonthly basis until 1 July 1978, for following reasons:

1. To obtain readings during the winter of 1977-1978 as these were anticipated to be exceptionally low as a result of the 1977 drought.
2. To obtain readings during the 1978 freshet as these were anticipated to be higher than those taken during the 1977 freshet, which was exceptionally low.
3. To obtain readings at Site 10-D, the intake site selected during the Preliminary Design Study. These readings were required to confirm the stage discharge curve developed during the Preliminary Design Study on the basis of water levels taken 180 m downstream of 10-D.

STATIONS

Readings were taken at the following stations, see Drawing A4251/5-1*:

1. Station 10-D: The selected intake site, 225 m (750 ft) upstream of Site 10 (Station 0).
2. Station 45 m (150 ft) Upstream: This station, 45 m upstream of Site 10 (Station 0), is for correlation of readings taken during 1976 - 1977 and 1977 - 1978.
3. Station 10-G: A potential backup site for 10-D, identified during the Preliminary Design Study. This station is 1220 m (4000 ft) downstream of Site 10 (Station 0).

* For drawings see Appendix 1.


4. Station 1939 m (6360 ft) Downstream: This station serves as downstream control for hydraulic computations with a submerged condition of the Thompson River rapids, located at the confluence with the Bonaparte River. Therefore, these readings were taken during the freshet only.

DATA


To obtain the water levels, Sandwell retained McElhanney Surveying and Engineering Ltd. who engaged Paul Genton, Land Surveyor of Clinton, to carry out the readings. Table 1 in Appendix 1 lists the readings together with mean daily flow rates at Spences Bridge, obtained from the Department of the Environment, Water Survey of Canada, Vancouver.

The hydrograph on Drawing D4251/5-2 illustrates how the water level readings cover the 1977 - 1978 low water period and the 1978 freshet, and also how these readings relate to both the hydrographs for 1976 and 1977, and the minimum and maximum flows on record.

Prepared by


J. W. C. Boyle

Approved by


A. Copeland, P. Eng.


APPENDIX 1

TABLE 1 AND ILLUSTRATIONS

Table 1 - Water Surface Elevations

| Date | 6360 Ft Downstream | | Station 10-G 4000 Ft Downstream | | 150 Ft Upstream | | Station 10-J 750 Ft Upstream | | Thompson River (see note 2) | |
|-----------|--------------------|--------|------------------------------------|--------|-----------------|--------|---------------------------------|--------|--------------------------------|-------------------|
| | Elevation | Change | Elevation | Change | Elevation | Change | Elevation | Change | Discharge | Change In |
| | m | m | m | m | m | m | m | m | m ³ /s | m ³ /s |
| 77 Dec 14 | - | - | 288.50 | - 0.17 | 289.87 | - 0.20 | 289.93 | - 0.19 | 218 | - 26 |
| Dec 31 | - | - | 288.33 | 0 | 289.67 | - 0.01 | 289.74 | - 0.01 | 192 | - 21 |
| 78 Jan 15 | - | - | 288.33 | - 0.14 | 289.66 | - 0.13 | 289.73 | - 0.14 | 171 | - 25 |
| Feb 1 | - | - | 288.19 | + 0.06 | 289.53 | + 0.02 | 289.59 | + 0.02 | 146 | + 19 |
| Feb 14 | - | - | 288.25 | - 0.06 | 289.55 | - 0.05 | 289.61 | - 0.05 | 165 | - 9 |
| Feb 28 | - | - | 288.19 | - 0.01 | 289.50 | - 0.01 | 289.56 | - 0.02 | 156 | - 3 |
| Mar 16 | - | - | 288.18 | + 0.31 | 289.49 | + 0.35 | 289.54 | + 0.36 | 153 | + 79 |
| Mar 31 | - | - | 288.49 | + 0.53 | 289.84 | + 0.62 | 289.90 | + 0.64 | 232 | + 119 |
| Apr 15 | - | - | 289.02 | + 1.65 | 290.46 | + 2.13 | 290.54 | + 2.18 | 351 | + 659 |
| May 15 | 289.63 | + 0.56 | 290.67 | + 0.51 | 292.59 | + 0.74 | 292.72 | + 0.72 | 1,010 | + 310 |
| May 31 | 290.19 | + 0.84 | 291.18 | + 1.03 | 293.33 | + 1.49 | 293.44 | + 1.46 | 1,320 | + 730 |
| June 15 | 291.03 | - 0.35 | 292.21 | - 0.36 | 294.82 | - 0.51 | 294.90 | - 0.46 | 2,050 | - 260 |
| July 1 | 290.68 | | 291.85 | | 294.31 | | 294.44 | | 1,790 | |



- Note: 1. This program of recording water levels was terminated on 1 July 1978 because the peak of the freshet had passed the intake site.
2. Discharges were obtained by subtracting Bonaparte and Nicola River flows (Stations 8LF02 and 8LG06) from Thompson River flow at Spences Bridge (Station 8LF51).
3. Low water level readings were terminated on 15 April 1978 and freshet water level readings were commenced on 15 May 1978.



| DWG. NO. | REFERENCE | REF. NO. | REV. BY | DATE | REVISION | APPRO |
|---|----------------|-----------------|---------|------|--|-------|
| APPROVED | SCALE 1:16,000 | DAY | MO. | YR. | HAT CREEK PROJECT COOLING WATER SUPPLY THOMPSON RIVER - WATER LEVEL DATA SITE 10 - STATIONS B.C. HYDRO AND POWER AUTHORITY VANCOUVER B.C. | |
| DATE | DR'N. D. TUNG | 5 | 6 | 78 | | |
| | CHK'D | | | | | |
| A 4251/5-1 | APP'D. | | | | | |
| | APP'D. A.C. | 31 | 7 | 78 | | |
| <small>THIS DRAWING IS THE PROPERTY OF SANDWELL AND MUST BE RETURNED TO SANDWELL ON REQUEST. ITS CONTENTS ARE SECRET AND CONFIDENTIAL. ANY INFORMATION OBTAINED BY INSPECTION OF THIS DRAWING SHALL NOT BE USED FOR ANY OTHER THAN THE SPECIFIC PURPOSE FOR WHICH ITS INSPECTION IS AUTHORIZED BY SANDWELL.</small> | | | | | | |
| SANDWELL | | DWG. A 4251/5-1 | | | REV | |

PROJECT MEMORANDUM V4251/5

THOMPSON RIVER - WATER LEVEL DATA



KEY PLAN

- LEGEND:
- WATER LEVELS TAKEN AT INTAKE SITE 10.
 - ⊙ FIELD VISITS MADE AT INTAKE SITE 10.
 - WATER SAMPLES TAKEN AT WALHACHIN BRIDGE.

- NOTES:
- THE DATA USED TO PLOT THESE HYDROGRAPHS FOR THE THOMPSON RIVER NEAR SPENCES BRIDGE WAS SUPPLIED BY THE WATER SURVEY OF CANADA.
 - THE 1977 & 1978 CURVES ARE BASED ON INCOMPLETE DATA AND, THEREFORE, THE PEAKS MAY NOT BE EXACTLY IN THE CORRECT POSITIONS.

RECORD OF FIELD VISITS AT INTAKE SITE 10

| NO. | DATE | REMARK |
|-----|-------------------|-------------------------|
| 1 | 20 MAY 1976 | FIRST HELICOPTER VISIT |
| 2 | 18 SEPT. 1976 | SECOND HELICOPTER VISIT |
| 3 | 22 FEB. 1977 | THIRD HELICOPTER VISIT |
| 4 | 15 & 16 JUNE 1977 | GROUND VISIT |
| 5 | 1 SEPT. 1977 | GROUND VISIT |
| 6 | 8 NOV. 1977 | FOURTH HELICOPTER VISIT |

| | | | | | |
|----------|---------|--------------------|------------|--|--|
| SANDWELL | | DWS. NO. D4751/5-2 | | BRITISH COLUMBIA HYDRO AND POWER AUTHORITY | |
| DES. | REC'D | | | HAT CREEK PROJECT | |
| OWN | D. TONG | APP'D | TECH | COOLING WATER SUPPLY | |
| CHK'D | JWB | APP'D | | THOMPSON RIVER - WATER LEVEL DATA | |
| REP. | | APP'D | R.C. | HYDROGRAPHS - 1976 THROUGH JULY 1978 | |
| SUBD. | | DATE | 31 JULY 78 | | |